

# J.C. Broderick & Associates, Inc.

Environmental / Construction Consulting & Testing



1775 Expressway Drive North  
Hauppauge, NY 11788  
631.584.5492  
Fax: 631.584.3395  
[www.jcbroderick.com](http://www.jcbroderick.com)

February 25, 2025

Mr. Thomas Szajkowski  
Roslyn Union Free School District  
Administration Building  
3 Parp Drive – PO Box 367  
Roslyn, New York 11576

Re: **Lead Testing in School Drinking Water  
Remedial Action Plan – Initial Report February 2025  
2023-2025 Compliance 10 NYCRR Subpart 67-4**

JCB#: 23-53787

Dear Mr. Szajkowski:

J.C. Broderick & Associates, Inc. (JCB) was retained to perform lead testing and analysis of the outlets which service the above referenced school district in accordance with 10 NYCRR Subpart 67-4 (Subpart 67-4).

The outlets servicing each of the school buildings were inventoried and assigned unique identification numbers. The use and location of each outlet was reviewed to determine its applicability for testing under Subpart 67-4.

An initial first-draw sample was collected from each applicable outlet after the minimum 8-hour stagnation period. Samples were logged into a chain of custody document and delivered to an Environmental Laboratory Approval Program (ELAP) accredited laboratory for analysis.

Results from the laboratory analysis were compared with the Action Level as defined by Subpart 67-4 of 5 parts per billion (ppb). Any outlet which exceeded this level requires a remediation action plan be implemented (i.e. removal from service, placarding for non-drinking uses). Outlets which did not exceed the action level do not require further testing or remediation.

Please see the following attachments which detail the sampling and analysis performed and remediation actions taken to date.

- Attachment 1: Lead in Water Remediation Plan
- Attachment 2: Outlet Inventory and Lead Testing Results
- Attachment 3: Laboratory Analytical Reports
- Attachment 4: Laboratory Certifications


If you have any questions, or if more information is needed, please contact our office.

Sincerely,

A handwritten signature in black ink, appearing to read 'Anthony J. Lombardo', is written over a light blue horizontal line.

Anthony J. Lombardo  
Project Manager  
**J.C. BRODERICK & ASSOCIATES, INC.**

Attachment 1:  
  
Lead in Water  
Remediation Plan



**J.C. Broderick & Associates, Inc.**  
*Environmental Consulting & Testing*  
1775 Expressway Drive North  
Hauppauge, New York 11788  
631.584.5492 fax 631.584.3395

# Lead in Water Remediation Plan

Section 67-4.4 Response of the New York State Department of Health (NYS DOH) Title 10 of the Official Compilation of the Codes, Rules and Regulations of the State of New York requires:

*If the lead concentration of water at an outlet exceeds the action level, the school shall:*

*(a) prohibit use of the outlet until:*

- (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and*
- (2) test results indicate that the lead levels are at or below the action level;*

As historical sampling results have indicated, the concentrations of lead are more likely attributable to the individual fixtures and/or their immediately adjoining plumbing, and not with the building-wide plumbing. Based upon this information, the following remedial steps are recommended:

## **Step 1A: Potable Outlets** (Outlets intended to be used for drinking/cooking)

Immediately remove the fixture from service. If necessary, provide an adequate supply of potable water for drinking/cooking to this location at no cost to the occupants. If an outlet is seldomly used or is unnecessary, the district may consider permanent removal of the outlet and capping of its supply line.

## **Step 1B: Non-Potable Outlets** (Outlets not intended for drinking/cooking)


See Step 1A OR Placard the outlet for non-drinking use. Signs must be clearly visible and in close proximity to the affected outlet. Example signage is provided at: [https://www.health.ny.gov/environmental/water/drinking/lead/docs/donotdrinksigns\\_lead .pdf](https://www.health.ny.gov/environmental/water/drinking/lead/docs/donotdrinksigns_lead.pdf).



Do not use for drinking



Hand washing only




## **Step 2: Service & Repair or Outlet Replacement**

The school district's plumber should evaluate the outlet to determine if any components require service or repair. Depending on the extent of service/repair necessary, age of the fixture, and or overall costs, the district may consider replacing the outlet entirely. Any newly installed components shall be certified lead free. (i.e. NSF/ANSI 61, NSF/ANSI-273). If servicing involves installing/replacing a point-of-use filtration system, this filter shall be certified for its lead reduction capability (i.e. NSF/ANSI 53). Follow all manufacturer's instructions for all component installations. OUTLET RESTRICTIONS MUST REMAIN IN PLACE UNTIL SATISFACTORY TEST RESULTS ARE RECEIVED. See Step 3.

## **Step 3: Retesting & Return to Service**

Schedule a retest of the outlet. Outlet restrictions must remain in place until lead testing results at or below the action level are received. Once satisfactory results are received, the outlet may be returned to normal service. Note: It is recommended that "Do Not Drink" signage remain in place for all non-potable and non-applicable outlet types.

Attachment 2:  
  
Outlet Inventory and  
Lead Testing Results



**J.C. Broderick & Associates, Inc.**  
*Environmental Consulting & Testing*  
1775 Expressway Drive North  
Hauppauge, New York 11788  
631.584.5492 fax 631.584.3395



# Laboratory Lead in Water Results

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787

## Roslyn Union Free School District

### East Hills Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0001	Boiler Room	0005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0002	Room 65	0011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0003	Room 64	0012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0005	Room 45	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0006	Room 44	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0007	Room 44	1001	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0008	Adult Bathroom Outside Room 44	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0009	Gender Neutral Bathroom Outside Room 45	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0010	Boys Bathroom Outside Room 43	1004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0011	Girls Bathroom Outside Room 46	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0013	Room 43	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0014	Room 46	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0015	Room 46	1007	Water Fountain-No Chiller	Potable	1/28/2025	2.9			Result Below Action Level Continue O&M
RSLN-0016	Room 47	1009	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0017	Room 47	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0018	Room 41	1010	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M

# East Hills Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0019	Room 41	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0020	Room 48	1011	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0021	Room 48	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0022	Room 40	1012	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0023	Room 40	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0024	Room 49	1013	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0025	Room 49	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0026	Room 39	1014	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0027	Room 39	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0028	Room 50	1015	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0029	Corridor Library To Room 47 (Outside Room 50)	1025	Bottle Fill Station	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0030	Room 50	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0031	Handicap Bathroom Outside Room 50	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0032	Boys Bathroom Across Library	1019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0033	Boys Bathroom Across Library	1019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0034	Custodial Closet Across Library	1020	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0035	Girl's Bathroom Across Library	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0036	Girl's Bathroom Across Library	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0037	Library	1024	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0038	Main Office Principals Office Bathroom	1026C2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# East Hills Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0039	Room 5 Health Office	1031A	Nurse's Office Sink	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0040	Room 5 Health Office Hallway Bathroom	1031B4	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0041	Corridor Room 19 To Room 22 (Outside Gym)	1051	Bottle Fill Station	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0042	Adult Bathroom Across Gym	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0043	Room 17 Faculty Lounge Bathroom	1042A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0045	Girls Bathroom Across Room 22	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0046	Girls Bathroom Across Room 22	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0047	Boys Bathroom Across Room 21	1044	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0048	Boys Bathroom Across Room 21	1044	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0049	Room 18	1046	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0050	Room 18	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0051	Room 19 Art Room	1047	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0052	Room 19 Art Room	1047	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0053	Custodial Closet	1045	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0054	Room 20	1048	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0055	Room 20	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0056	Room 20 Bathroom	1048B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0057	Room 21	1049	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0058	Room 21	1049	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0059	Room 21 Bathroom	1049B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# East Hills Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0060	Room 22	1050	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0061	Room 22	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0062	Room 22 Bathroom	1050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0063	Custodial Closet	1052	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0064	Room 23	1056	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0065	Room 23	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0066	Room 23 Bathroom	1056A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0067	Room 24	1057	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0068	Room 24	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0070	Room 25	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0071	Room 25 Bathroom	1058B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0072	Room 25	1058	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0073	Kitchen	1061A	Kitchen Faucet (Cold)	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0074	Kitchen	1061A	Kitchen Faucet (Cold)	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0075	Kitchen	1061A	Kitchen Faucet (Cold)	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0076	Kitchen	1061A	Kitchen Faucet (Cold)	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0077	Kitchen	1061A	Kitchen Faucet (Cold)	Potable	1/28/2025	2.1			Result Below Action Level Continue O&M
RSLN-0078	Kitchen	1061A	Spray Nozzle	Potable	1/28/2025	1.2			Result Below Action Level Continue O&M
RSLN-0079	Kitchen	1061A	Spray Nozzle	RFI	1/28/2025	9.5			Outlet Permanently Removed
RSLN-0080	Corridor Room 27 To 29 (Outside Room 27)	1066	Water Cooler	Potable	9/19/2024		1/28/2025	OOS	Testing Required Before Return to Service

# East Hills Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0082	Room 27	1062	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0083	Room 27	1062	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0084	Room 28	1063	Water Fountain-No Chiller	Potable	1/28/2025	1.3			Result Below Action Level Continue O&M
RSLN-0086	Room 28	1063	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0089	Room 29	1064	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0090	Room 29	1064	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0091	Room 29 Bathroom	1064B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0092	Women's Bathroom	1068	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0093	Men's Bathroom	1069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0094	Custodial Closet	1070	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0095	Room 58	2001	Water Fountain-No Chiller	Potable	1/28/2025	2.1			Result Below Action Level Continue O&M
RSLN-0096	Room 58	2001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0097	Room 57	2002	Water Fountain-No Chiller	Potable	1/28/2025	1.6			Result Below Action Level Continue O&M
RSLN-0098	Room 57	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0099	Room 56 Bathroom	2003A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0100	Room 59	2005	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0101	Room 59	2005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0102	Room 55	2006	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0103	Room 55	2006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0104	Room 60	2007	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M

# East Hills Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0105	Room 60	2007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0106	Room 54	2008	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0107	Room 54	2008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0108	Room 61	2009	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0109	Room 61	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0110	Room 53	2010	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0111	Room 53	2010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0112	Room 62	2011	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0113	Room 62	2011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0114	Room 52	2012	Water Fountain-No Chiller	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0115	Room 52	2012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0116	2nd Floor Girls Bathroom	2015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0117	2nd Floor Girls Bathroom	2015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0118	2nd Floor Custodial Closet	2014	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0119	2nd Floor Boy's Bathroom	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0120	2nd Floor Boy's Bathroom	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0717	Corridor Library To Room 47 (Outside Room 50)	1025	Water Cooler	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0718	Corridor Room 19 To Room 22 (Outside Gym)	1051	Water Cooler	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0778	Corridor Room 27 To 29 (Outside Room 27)	1066	Bottle Fill Station	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0779	Corridor Room 27 To 29 (Outside Room 27)	1066	Water Cooler	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M

# East Hills Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0780	<b>2nd Floor Corridor (Outside Room 51)</b>	2018	Bottle Fill Station	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0781	<b>2nd Floor Corridor (Outside Room 51)</b>	2018	Water Cooler	Potable	1/28/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0844	<b>Room 43</b>	1006	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0846	<b>Room 24 Bathroom</b>	1057A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0847	<b>Room 27 Bathroom</b>	1062B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0848	<b>Room 28 Bathroom</b>	1063B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0999	<b>Room 17 Faculty Lounge</b>	1042	Kitchen Faucet (Cold)	Potable	1/28/2025	4.7			Result Below Action Level Continue O&M

# Harbor Hill Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0122	Room 59 Custodial Office	1036C	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0125	Girls Bathroom Across Room 25	1000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0126	Girls Bathroom Across Room 25	1000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0127	Girls Bathroom Across Room 25	1000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0128	Custodial Closet	1001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0133	Room 25	1003	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0134	Room 25	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0135	Room 24	1004	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0136	Room 24	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0137	Room 27	1005	Water Fountain-No Chiller	Potable	1/29/2025	5.4	2/17/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
RSLN-0138	Room 27	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0139	Room 26	1006	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0140	Room 26	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0141	Room 26 South Bathroom	1006A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0142	Room 29	1007	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0143	Room 29	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0144	Room 31	1009	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0145	Room 31	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0146	Library Room 32	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0147	Room 33	1011	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M

# Harbor Hill Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0148	Room 33	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0149	Boys Bathroom Outside Gym	1015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0150	Boys Bathroom Outside Gym	1015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0151	Girls Bathroom Outside Gym	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0152	Girls Bathroom Outside Gym	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0153	Gym South Office Bathroom	1017A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0154	Gym North Office Bathroom	1017C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0155	Gym Vestibule	1018	Bottle Fill Station	Potable	1/29/2025	1.1			Result Below Action Level Continue O&M
RSLN-0156	Room 42 Art Room	1021	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0157	Room 42 Art Room	1021	Water Fountain-No Chiller	Potable	1/29/2025	OOS			Testing Required Before Return to Service
RSLN-0158	Room 42 Art Room	1021	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0159	Room 44	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0160	Room 44	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0161	Nurses Office	1029	Nurse's Office Sink	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0162	Nurses Office Bathroom	1029C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0163	Cafeteria/Auditorium	1030	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0164	Kitchen	1031A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0165	Kitchen	1031A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0166	Kitchen	1031A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0167	Kitchen	1031A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M

# Harbor Hill Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0168	Kitchen	1031A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0169	Kitchen	1031A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0170	Kitchen Bathroom	1031A3	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0172	Incinerator Room	1035	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0173	Faculty Restroom Outside Music Room	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0174	Custodial Closet	1039	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0176	Faculty Room Bathroom	1041A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0177	Principal Office Bathroom	1043B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0178	Custodial Closet Service Outside Room 10	1052	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0180	Room 10	1053	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0181	Room 10	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0182	Room 10 Bathroom	1053A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0183	Room 11	1054	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0184	Room 11	1054	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0185	Room 11 Bathroom	1054B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0186	Room 12	1055	Water Fountain-No Chiller	Potable	1/29/2025	OOS			Testing Required Before Return to Service
RSLN-0187	Room 12	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0189	Room 13	1056	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0190	Room 13	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0191	Room 13 Bathroom	1056B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Harbor Hill Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0192	Room 14	1057	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0193	Room 14	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0194	Room 14 Bathroom	1057B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0195	Room 15	1058	Water Fountain-No Chiller	Potable	1/29/2025	2.4			Result Below Action Level Continue O&M
RSLN-0196	Room 15	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0197	Room 15 Bathroom	1058A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0198	Room 18	1060	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0199	Room 18	1060	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0200	Room 18 Bathroom	1060A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0201	Room 17	1061	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0202	Room 17	1061	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0203	Room 17 Bathroom	1061B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0204	Room 19	N/A	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0205	Room 20	N/A	Water Fountain-No Chiller	Potable	1/29/2025	1.6			Result Below Action Level Continue O&M
RSLN-0206	Room 21	N/A	Water Fountain-No Chiller	Potable	1/29/2025	6.5	2/17/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
RSLN-0207	Room 22	N/A	Water Fountain-No Chiller	Potable	1/29/2025	1.2			Result Below Action Level Continue O&M
RSLN-0208	Room 23	N/A	Water Fountain-No Chiller	Potable	1/29/2025	4.1			Result Below Action Level Continue O&M
RSLN-0209	Room 19	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0210	Room 20	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0211	Room 21	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Harbor Hill Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0212	Room 22	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0213	Room 23	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0214	Boys Bathroom (Rooms 19-23 Wing)	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0215	Boys Bathroom (Rooms 19-23 Wing)	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0216	Girls Bathroom (Rooms 19-23 Wing)	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0217	Girls Bathroom (Rooms 19-23 Wing)	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0218	Gender Neutral Bathroom (Rooms 19-23 Wing)	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0219	Multipurpose Room	N/A	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0220	Multipurpose Room	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0221	Multipurpose Room	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0222	Room 50 Computer Lab	2000	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0223	Room 50 Computer Lab	2000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0224	Room 51	2001	Water Fountain-No Chiller	Potable	1/29/2025	1.8			Result Below Action Level Continue O&M
RSLN-0225	Room 51	2001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0226	Room 52	2002	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0227	Room 52	2002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0228	Room 53	2003	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0229	Room 53	2003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0230	Room 54	2004	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0231	Room 54	2004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Harbor Hill Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0232	Room 55	2005	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0233	Room 55	2005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0234	Room 56	2006	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0235	Room 56	2006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0236	Room 57	2007	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0237	Room 57	2007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0239	Room 58	2008	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0240	Room 58	2008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0241	2nd Floor Boys Bathroom	2009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0242	2nd Floor Boys Bathroom	2009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0243	2nd Floor Boys Bathroom	2009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0244	Custodial Closet	2010	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0245	2nd Floor Girls Bathroom	2011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0246	2nd Floor Girls Bathroom	2011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0247	2nd Floor Girls Bathroom	2011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0483	Gym Vestibule	1018	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0484	Multipurpose Room	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0729	Cafeteria/Auditorium	1030	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0730	Gym Vestibule	1018	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0784	Main Lobby Corridor (Outside Room 9)	1051	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M

# Harbor Hill Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0785	Main Lobby Corridor (Outside Room 9)	1051	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0786	Corridor Room 25 To Gymnasium (Outside Room	1012	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0787	Corridor Room 25 To Gymnasium (Outside Room	1012	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0788	Corridor Room 50 To Room 58 (Outside Room 58)	2012	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0789	Corridor Room 50 To Room 58 (Outside Room 58)	2012	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0892	Boys Bathroom Across Room 25	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0893	Boys Bathroom Across Room 25	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0894	Boys Bathroom Across Room 25	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0895	Room 44	1027	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0896	Exit Vestibule Bathroom	1034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0897	Faculty Room	1041	Kitchen Faucet (Cold)	Potable	1/29/2025	25.9	2/17/2025	2.0	Outlet Remediated and Returned to Service Continue O&M
RSLN-0898	Room 12 Bathroom	1055A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-1005	Nurses Office	1029	Spray Nozzle	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-1006	Nurses Office	1029	Ice Machine	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-1010	Kitchen	1031A	Spray Nozzle	Non-Applicable	1/29/2025	12.1			Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use

# Heights Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0248	Science & Art Room	0007	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0249	Science & Art Room	0007	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0250	Bathroom Outside Room 7	0008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0251	Corridor Gym To Room 1 (Outside Library)	0019	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0252	Exit Vestibule Sump Pump Room	0012A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0253	Bathroom Outside Room 2	0013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0254	Faculty Lounge	0016	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0255	Faculty Lounge Bathroom	0016A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0256	Room 2	0018	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0257	Room 2	0018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0258	Room 1	0017	Water Fountain-No Chiller	Potable	1/29/2025	3.1			Result Below Action Level Continue O&M
RSLN-0259	Room 1	0017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0260	Room 11	1000	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0261	Room 11	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0262	Room 12	1001	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0263	Room 12	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0264	Custodial Storage	1002	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0265	Boys Bathroom Across Room 13	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0266	Boys Bathroom Across Room 13	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0267	Boys Bathroom Across Room 13	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Heights Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0268	Boys Bathroom Staff Bathroom	1003A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0269	Corridor Room 11 To Room 15 (Outside Room 13)	1019	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0270	Room 13	1004	Water Fountain-No Chiller	Potable	1/29/2025	1.2			Result Below Action Level Continue O&M
RSLN-0271	Room 13	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0272	Kitchen	1006A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0273	Kitchen	1006A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0274	Kitchen	1006A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0275	Cafeteria Bathroom	1006B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0276	Corridor Room 11 To Room 15 (Room 10)	1019	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0277	Girls Bathroom Across Room 14	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0278	Girls Bathroom Across Room 14	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0279	Nurse's Office	1016	Ice Machine	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0280	Nurse's Office Bathroom	1016A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0281	Room 15	1017	Water Fountain-No Chiller	Potable	1/29/2025	3.0			Result Below Action Level Continue O&M
RSLN-0282	Room 15	1017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0283	Room 14	1018	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0284	Room 14	1018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0285	Breeze Way	1021	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0286	Breeze Way	1021	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0287	Faculty Bathroom	1014A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Heights Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0288	Room 32	1024	Water Fountain-No Chiller	Potable	1/29/2025	1.0			Result Below Action Level Continue O&M
RSLN-0289	Room 32	1024	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0290	Room 32 Bathroom	1024A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0292	Room 28	1025	Water Fountain-No Chiller	Potable	1/29/2025	1.5			Result Below Action Level Continue O&M
RSLN-0293	Room 28	1025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0294	Room 29	1028	Water Fountain-No Chiller	Potable	1/29/2025	3.7			Result Below Action Level Continue O&M
RSLN-0296	Room 33	1030	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0297	Room 33	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0298	Room 33 Bathroom	1030A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0299	Room 34	1032	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0300	Room 34	1032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0301	Room 34 Bathroom	1032B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0302	Room 30	1034	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0303	Room 30	1034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0305	Custodial/Kiln Closet	1036	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0306	Room 31	1037	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0308	Library Work Room	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0309	Main Office 41 Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0310	Room 27	2000	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0311	Room 27	2000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Heights Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0312	Room 24	2001	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0313	Room 24	2001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0314	2nd Floor Girls Bathroom	2004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0315	2nd Floor Girls Bathroom	2004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0316	2nd Floor Girls Bathroom Staff Bathroom	2004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0317	Room 25	2006	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0318	Second Floor Corridor (Outside Room 25)	2016	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0319	Room 25	2006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0320	Room 23	2009	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0321	Room 23	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0322	2nd Floor Boys Bathroom	2012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0323	2nd Floor Boys Bathroom	2012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0324	2nd Floor Boys Bathroom	2012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0325	Custodial Closet	2013	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0326	Room 22	2014	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0327	Room 22	2014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0328	Room 21	2015	Water Fountain-No Chiller	Potable	1/29/2025	1.0			Result Below Action Level Continue O&M
RSLN-0329	Room 21	2015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0719	Room 31	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0720	Room 29	1028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Heights Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0721	Room 28	1025	Water Fountain-No Chiller	Potable	1/29/2025	OOS			Testing Required Before Return to Service
RSLN-0722	Kitchen	1006A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0731	Room 29	1028	Water Fountain-No Chiller	Potable	1/29/2025	OOS			Testing Required Before Return to Service
RSLN-0776	Room 10	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0777	Room 10	N/A	Water Fountain-No Chiller	Potable	1/29/2025	263	2/21/2025	1.0	Outlet Remediated and Returned to Service Continue O&M
RSLN-0899	Corridor Gym To Room 1 (Outside Library)	0019	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0900	Corridor Room 11 To Room 15 (Outside Room 13)	1019	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0901	Corridor Room 11 To Room 15 (Room 10)	1021	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0902	Breeze Way	1021	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0903	Room 28 Bathroom	1025B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0904	Room 29 Bathroom	1028A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0905	Room 30 Bathroom	1034B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0906	Room 31 Bathroom	1037A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0907	Second Floor Corridor (Outside Room 25)	2016	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-1003	Cafeteria Kitchen	1006A	Spray Nozzle	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-1004	Cafeteria Kitchen	1006A	Spray Nozzle	Potable	1/29/2025	1.2			Result Below Action Level Continue O&M

# Roslyn Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0330	Boiler Room Corridor	0003	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0331	Boiler Room Corridor	0003	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0332	Custodial Storage/Lounge	0004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0336	Room 101	1004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0337	Room 101	1004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0338	Room 101	1004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0339	Room 101	1004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0340	Room 101	1004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0342	Science Prep Room	1005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0343	Room 103	1006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0344	Room 103	1006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0345	Room 103	1006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0346	Room 103	1006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0349	Room 103	1006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0350	Room 103	1006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0353	Room 112	1014	Kitchen Faucet (Cold)	Potable	1/29/2025	2.9			Result Below Action Level Continue O&M
RSLN-0355	Boys Bathroom Across Room 111	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0356	Boys Bathroom Across Room 111	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0357	Boys Bathroom Across Room 111	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0358	Custodial Closet	1019	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0359	Girls Bathroom Across Room 111	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0360	Girls Bathroom Across Room 111	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0361	Girls Bathroom Across Room 111	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0362	Corridor (Girls BR-Elevator Vestibule) (Outside Room 112)	1021	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0363	Library	1022	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0364	Art Room 119	1025	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0365	Art Room 119	1025	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0366	Conference Room 118 Bathroom	1027A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0367	Corridor (o/s Nurse's Office)	1072	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0368	Corridor (o/s Nurse's Office)	1072	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0369	Custodial Storage	1030	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0370	Boys Bathroom Across Aux Gym	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0371	Boys Bathroom Across Aux Gym	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0372	Boys Bathroom Across Aux Gym	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0373	Girls Bathroom Across Aux Gym	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0374	Girls Bathroom Across Aux Gym	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0375	Girls Bathroom Across Aux Gym	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0376	Home & Career Lab Room 611	1035	Home Economics Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0377	Home & Career Lab Room 611	1035	Home Economics Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0378	Home & Career Lab Room 611	1035	Home Economics Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M

# Roslyn Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0379	Home & Career Lab Room 611	1035	Home Economics Faucet (Cold)	Potable	1/29/2025	2.7			Result Below Action Level Continue O&M
RSLN-0380	Girls Locker Room	1036A	Water Fountain-No Chiller	Potable	1/29/2025	2.6			Result Below Action Level Continue O&M
RSLN-0381	Girls Locker Room	1036A	Water Fountain-No Chiller	Potable	1/29/2025	3.2			Result Below Action Level Continue O&M
RSLN-0382	Boys Locker Room Bathroom	1042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0383	Boys Locker Room Bathroom	1042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0384	Boys Locker Room Bathroom	1042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0385	Girls Locker Room Coaches Office Bathroom	1036B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0386	Corridor (Custodial Storage-Corridor 1031) (Outside Aux	1045	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0387	Corridor (Custodial Storage-Corridor 1031) (Outside Aux	1045	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0390	Art Room 121	1039	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0391	Art Room 121	1039	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0393	Kitchen	1040B2	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0395	Kitchen	1040B2	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0396	Kitchen	1040B2	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0397	Cafeteria North Serving Room Kitchen Locker Room	1040B2C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0398	Cafeteria North Serving Room Kitchen Laundry Room	1040B2E	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0399	Cafeteria South	1041	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0400	Girls Locker Room Bathroom	1036A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0401	Girls Locker Room Bathroom	1036A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0402	Girls Locker Room Bathroom	1036A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0403	Boys Locker Room	1042A	Water Fountain-No Chiller	Potable					Testing Required Before Return to Service
RSLN-0404	Boys Locker Room	1042A	Water Fountain-No Chiller	Potable					Testing Required Before Return to Service
RSLN-0405	Boys Locker Room Coaches Office Bathroom	1042A2A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0406	Custodial Storage	1044	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0407	Boiler Room Stairwell Bathroom	1046A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0408	Handicap Bathroom	1047	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0409	Faculty Room	1048	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0410	Faculty Room Men's Bathroom	1048A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0411	Faculty Room Women's Bathroom	1048B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0412	Boys Bathroom Across Aud	1055	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0413	Boys Bathroom Across Aud	1055	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0414	Custodial Closet	1056	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0415	Girls Bathroom Across Aud	1057	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0416	Girls Bathroom Across Aud	1057	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0417	Tech A (pupil personnel services)	1060	Kitchen Faucet (Cold)	Potable	1/29/2025	9.1	2/17/2025	3.5	Outlet Remediated and Returned to Service Continue O&M
RSLN-0421	Health Office	1070	Nurse's Office Sink	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0422	Health Office Exam Room	1070A	Nurse's Office Sink	Potable	1/29/2025	6.4	2/17/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
RSLN-0423	Health Office Bathroom	1070B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0424	Athletic Trainer Office	N/A	Ice Machine	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0425	Athletic Trainer Office	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0426	Main Office Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0428	Gymnasium Boys Locker Room Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0429	Gymnasium Boys Locker Room Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0430	Gymnasium Girls Locker Room Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0431	Gymnasium Girls Locker Room Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0432	Gymnasium Girls Locker Room Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0433	Gymnasium P.E. Office Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0434	Science Lab Room 609	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0435	Science Lab Room 609	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0436	Science Lab Room 609	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0437	Science Lab Room 609	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0438	Science Lab Room 609	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0439	Science Lab Room 609	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0440	Science Lab Room 609	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0441	Science Lab Room 609	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0442	Science Lab Room 609	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0443	Science Lab Room 610	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0444	Science Lab Room 610	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0445	Science Lab Room 610	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0446	Science Lab Room 610	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0447	Science Lab Room 610	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0448	Science Lab Room 610	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0449	Science Lab Room 610	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0450	Science Lab Room 610	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0451	Science Lab Room 610	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0453	Science Lab Room 609/610 Prep Room	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0454	Girls Bathroom Across Room 201	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0455	Girls Bathroom Across Room 201	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0456	Girls Bathroom Across Room 201	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0458	Custodial Closet	2003	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0459	Boys Bathroom Across Room 203	2004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0460	Boys Bathroom Across Room 203	2004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0461	Boys Bathroom Across Room 203	2004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0462	Room 211	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0463	Room 211	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0464	Room 211	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0465	Room 211	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0466	Room 211	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0467	Room 211	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0468	Room 211	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0469	Room 211	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0470	Room 211	2015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0471	Science Prep Room	2016	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0475	Room 213	2017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0476	Room 213	2017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0477	Room 213	2017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0481	Exterior Hose Bib o/s Gymnasium	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0482	Exterior Hose Bib o/s Gymnasium	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0741	Corridor (o/s Nurse's Office)	1072	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0742	Cafeteria South	1041	Water Fountain-No Chiller	Potable					Testing Required Before Return to Service
RSLN-0782	2nd Floor Corridor	2023	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0783	2nd Floor Corridor	2023	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0806	Corridor (Tech A-Boys Bathroom) (Outside Tech A	1061	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0807	Corridor (Tech A-Boys Bathroom) (Outside Tech A	1061	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0849	Room 123	1062	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0850	Tech A (pupil personnel services)	1060	Bottled Water Dispenser (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0851	Tech A (pupil personnel services)	1060	Bottled Water Dispenser (Hot)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0852	Kitchen	1040B2	Kitchen Faucet (Cold)	Potable	1/29/2025	3.7			Result Below Action Level Continue O&M
RSLN-0853	Kitchen	1040B2	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0854	Room 101	1004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0855	Room 101	1004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0856	Room 101	1004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0857	Room 101	1004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0858	Room 101	1004	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0859	Room 103	1006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0860	Room 103	1006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0861	Room 103	1006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0862	Room 103	1006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0863	Room 107 Bathroom	1011A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0864	Room 112 Bathroom	1014A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0865	Corridor (Girls BR-Elevator Vestibule) (Outside Room 112)	1021	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0866	Corridor (Room 611-Corridor 1031) (Outside Room 600)	1038	Water Cooler	Potable					Testing Required Before Return to Service
RSLN-0867	Corridor (Room 611-Corridor 1031) (Outside Room 600)	1038	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0868	Corridor (Room 129-Exit) (Outside Room 133)	1068	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0869	Corridor (Room 129-Exit) (Outside Room 133)	1068	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0870	Health Office	1070	Ice Machine	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0871	Gymnasium Boys Locker Room Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0872	Athletic Trainer Office	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0873	Science Lab Room 609	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0874	Science Lab Room 610	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0875	Room 211	2015	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0876	Room 213	2017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0877	Room 213	2017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0878	Room 213	2017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0879	Room 213	2017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0880	Room 213	2017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0881	Room 213	2017	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0882	Room 213	2017	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-1000	Room 112	1014	Spray Nozzle	Potable	1/29/2025	3.3			Result Below Action Level Continue O&M
RSLN-1001	Kitchen	1040B2	Spray Nozzle	Potable	1/29/2025	3.7			Result Below Action Level Continue O&M
RSLN-1002	Kitchen	1040B2	Spray Nozzle	Potable	1/29/2025	1.3			Result Below Action Level Continue O&M

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0486	Faculty Womens Bathroom	0004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0487	Faculty Womens Bathroom	0004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0488	Custodial Closet	0005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0489	Faculty Mens Bathroom	0006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0490	Faculty Mens Bathroom	0006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0491	Custodial Lounge	0014	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0492	Basement Custodial Storage/Bathroom	0016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0493	Auditorium Vestibule	1004	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0495	Auditorium Vestibule Men's Bathroom	1000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0496	Auditorium Vestibule Men's Bathroom	1000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0497	Custodial Closet	1001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0498	Auditorium Vestibule Single Use Bathroom	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0499	Auditorium Vestibule Women's Bathroom	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0500	Auditorium Vestibule Women's Bathroom	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0501	Room 138	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0502	Foreign Language Study Center	1016	Bottled Water Dispenser (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0503	Foreign Language Study Center	1016	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0504	Room 128	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0505	Room 128	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0506	Room 128	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0507	Room 128	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0508	Room 128	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0509	Room 128	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0510	Room 128	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0511	Room 128	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0512	Room 128	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0519	Room 127	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0520	Room 127	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0521	Room 127	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0522	Room 127	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0523	Room 127	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0524	Room 127	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0525	Room 127	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0526	Room 127	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0527	Earth Science Prep Room	1023A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0536	Room 126	1025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0537	Room 126	1025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0538	Room 126	1025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0539	Room 126	1025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0540	Room 126	1025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0541	Room 126	1025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0542	Room 126	1025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0543	Room 126	1025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0545	Women's Bathroom Across Room 130	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0546	Women's Bathroom Across Room 130	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0547	Women's Bathroom Across Room 130	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0548	Men's Bathroom Across Room 130	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0549	Men's Bathroom Across Room 130	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0550	Men's Bathroom Across Room 130	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0552	Room 124/125 Science Offices	1031	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0554	Librarian Office	1037B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0557	Women's Bathroom Across Main Gym	1040	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0558	Women's Bathroom Across Main Gym	1040	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0559	Men's Bathroom Across Main Gym	1041	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0560	Men's Bathroom Across Main Gym	1041	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0561	Custodial Closet	1042	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0568	Boys Locker Room Bathroom/Showers	1051A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0569	Boys Locker Room Bathroom/Showers	1051A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0570	Boys Locker Room Bathroom/Showers	1051A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0571	Custodial Closet Outside BLR	1052	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0572	Photo Lab	1056	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0573	Photo Lab	1056	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0574	Photo Lab	1056	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0575	Photo Lab Dark Room	1056B	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0576	Photo Lab Dark Room	1056B	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0580	Men's Bathroom	1062	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0581	Men's Bathroom	1062	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0582	Custodial Closet	1063	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0583	Faculty Women's Bathroom	1064	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0584	Women's Bathroom	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0585	Women's Bathroom	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0586	English Prep Room Kitchen	1071B	Kitchen Faucet (Cold)	Potable	1/29/2025	1.8			Result Below Action Level Continue O&M
RSLN-0589	Room 113	1084	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0590	Room 113	1084	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0592	Room 114	1089	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0593	Room 114	1089	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0594	Room 115	1090	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0595	Room 115	1090	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0597	Nurses Office	1092	Nurse's Office Sink	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0598	Nurses Office Bathroom	1092C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0599	Faculty Lounge Bathroom	1093A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0600	Faculty Lounge Women's Bathroom	1093C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0601	Faculty Lounge	1093	Kitchen Faucet (Cold)	Potable	1/29/2025	1.1			Result Below Action Level Continue O&M
RSLN-0602	Custodial Closet	1094	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0603	Main Office Gender Neutral Bathroom 1	1099G	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0604	Main Office Gender Neutral Bathroom 2	1099J	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0605	Main Office Conference Room	1099K	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0606	Main Office Back Hallway	1099M	Water Cooler	Potable	1/29/2025	OOS			Testing Required Before Return to Service
RSLN-0609	Kitchen	1102	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0610	Kitchen	1102	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0611	Kitchen	1102	Kitchen Faucet (Cold)	Potable	1/29/2025	1.4			Result Below Action Level Continue O&M
RSLN-0612	Kitchen	1102	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0613	Kitchen	1102	Kitchen Faucet (Cold)	Potable	1/29/2025	2.8			Result Below Action Level Continue O&M
RSLN-0614	Kitchen	1102	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0615	Kitchen	1102	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0617	Kitchen Serving Line	1102A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0618	Kitchen Serving Line	1102A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0619	Kitchen Serving Line	1102A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0620	Kitchen Custodial Closet	1102F	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0621	Kitchen Women's Bathroom	1102H	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0622	Unisex Bathroom	1104	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0623	Unisex Bathroom	1105	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0624	Corridor Outside North Gym	N/A	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0625	Corridor Outside North Gym	N/A	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0627	Corridor Girls Locker Room- Main Gym (Outside GLR)	1054	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0629	Men's Bathroom Across Room 209	2001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0630	Men's Bathroom Across Room 209	2001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0631	Custodial Closet	2002	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0632	Single Use Bathroom Across Room 210	2004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0633	Women's Bathroom Across Room 210	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0634	Women's Bathroom Across Room 210	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0635	Social Studies Offices	2008	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0636	Athletic Team Room	2023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0637	Athletic Team Room	2023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0638	Training Room	2024B	Ice Machine	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0639	Training Vestibule	2024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0640	Training Vestibule	2024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0641	Training Vestibule	2024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0642	Custodial Storage	2024D	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0644	Men's Bathroom Across Room 230	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0645	Men's Bathroom Across Room 230	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0646	Men's Bathroom Across Room 230	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0647	Custodial Closet	2031	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0648	Science Corridor Rooms 224-232 (Outside Room 230)	2043	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0649	Women's Bathroom Across Room 230	2032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0650	Women's Bathroom Across Room 230	2032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0651	Women's Bathroom Across Room 230	2032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0652	Room 224	2033	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0653	Room 224	2033	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0654	Room 224	2033	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0655	Room 224	2033	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0656	Room 224	2033	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0657	Room 224	2033	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0658	Room 224	2033	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0659	Room 224	2033	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0660	Room 224	2033	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0689	Math Offices	2046	Kitchen Faucet (Cold)	Potable	1/29/2025	1.3			Result Below Action Level Continue O&M
RSLN-0691	Room 242	2057	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0692	Women's Bathroom Outside Room 240	2064	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0693	Women's Bathroom Outside Room 240	2064	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0694	Single Use Bathroom	2065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0695	Custodial Closet	2066	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0696	Men's Bathroom Outside Room 240	2067	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0697	Men's Bathroom Outside Room 240	2067	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0699	Room 303	3002	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0700	Exterior Hose Bib o/s Field House	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0723	Band Room Instrument Storage	1096A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0724	Custodial Closet	1029	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0726	Room 126	1025	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0727	Room 127	1023	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0745	Corridor Outside North Gym	N/A	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0747	Science Corridor Rooms 224-232 (Outside Room 230)	2043	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0750	Field House	N/A	Ice Machine	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0752	Exterior Water Fountain o/s Field House (By Track)	N/A	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0753	Field House Boy's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0754	Field House Boy's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0755	Field House Boy's Bathroom Custodial Closet	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0756	Field House Girl's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0757	Field House Girl's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0765	Corridor Girls Locker Room-Main Gym (Outside GLR)	1054	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0769	Girls Locker Room Coaches Office Bathroom	1048A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0770	Girl's Locker Room	1048B	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0771	Girl's Locker Room	1048B	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0772	Girls Locker Room Bathroom	1048B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0773	Girls Locker Room Bathroom	1048B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0774	Girls Locker Room Bathroom	1048B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0775	Girls Locker Room Bathroom	1048B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0790	Basement Corridor (Outside Room 1)	0009	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0791	Basement Corridor (Outside Room 1)	0009	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0792	Corridor Orchestra-Guidance (Outside Nurses Office)	1098	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0793	Corridor Orchestra-Guidance (Outside Nurses Office)	1098	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0794	Corridor Room 107-111 (Outside Room 100)	1081	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0795	Corridor Room 107-111 (Outside Room 100)	1081	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0796	Boys Locker Room	1051	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0797	Boys Locker Room	1051	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0798	Corridor O/S Athletics Rooms	2027	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0799	Corridor O/S Athletics Rooms	2027	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0800	Science Corridor (Outside Room 130)	1034	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0801	Science Corridor (Outside Room 130)	1034	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0804	Corridor Rooms 234-240 (Across Projection Booth)	2068	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0805	<b>Corridor Rooms 234-240 (Across Projection Booth)</b>	2068	Water Cooler	Potable	<b>1/29/2025</b>	<b>&lt;1.00 ND</b>			Result Below Action Level Continue O&M
RSLN-0816	<b>Room 130</b>	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0817	<b>Room 130</b>	1026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0818	<b>Room 131 Computer Room</b>	1024B	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0819	<b>Room 131</b>	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0820	<b>Room 131</b>	1024	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0821	<b>Room 132</b>	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0822	<b>Room 132</b>	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0823	<b>Room 132</b>	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0824	<b>Room 132</b>	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0825	<b>Room 232</b>	2039	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0826	<b>Room 232</b>	2039	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0827	<b>Room 232</b>	2039	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0828	<b>Room 232</b>	2039	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0829	<b>Room 231</b>	2036	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0830	<b>Room 231</b>	2036	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0832	<b>Room 231</b>	2036	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0834	<b>Room 231</b>	2036	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0835	<b>Room 231</b>	2036	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0836	<b>Prep Area Between Room 230 &amp; 231</b>	2034A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0837	Room 230	2034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0838	Room 230	2034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0840	Room 230	2034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0842	Room 230	2034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0843	Room 230	2034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0913	Field House	N/A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0914	Auditorium Vestibule	1004	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0915	Auditorium Vestibule	1004	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0916	Foreign Language Study Center	1016	Bottled Water Dispenser (Hot)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0917	Room 128	1020	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0918	Room 128	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0919	Room 132 (Refrigerator)	1021	Water Cooler	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0920	Room 132 (Refrigerator)	1021	Ice Machine	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0921	Room 132	1021	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0922	Room 132	1021	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0923	Room 132 Prep Room	1021A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0924	Room 132 Greenhouse	1021A1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0925	Room 132 Greenhouse	1021A1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0926	Room 127	1023	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0927	Room 127	1023	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0928	Room 126	1025	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0929	Room 126	1025	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0930	Room 131A	1024A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0931	Room 131A	1024A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0932	Room 131A	1024A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0933	Room 130	1026	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0934	Room 123	1032	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0935	Room 123	1032	Spray Nozzle	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0936	Corridor Between Main Gym And DECA (Outside Main Gym)	1043	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0937	Corridor Between Main Gym And DECA (Outside Main Gym)	1043	Bottle Fill Station	Potable	1/29/2025	12.5	2/17/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
RSLN-0938	Single Use Bathroom o/s North Gym	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0939	Photo Lab	1056	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0940	Photo Lab Dark Room	1056B	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0941	Rev Lab	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0942	Rev Lab	1058	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0943	Rev Lab	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0944	Rev Lab	1058	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0945	Room 112	1083	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0946	Room 112	1083	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0947	Guidance Kitchen	1088M	Bottled Water Dispenser (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0948	Guidance Kitchen	1088M	Bottled Water Dispenser (Hot)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0949	Room 115	1090	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0950	Room 115	1090	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0951	Room 115	1090	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0952	Room 115	1090	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0953	Nurse Exam Room 3	1092D1	Nurse's Office Sink	Potable	1/29/2025	48.7	2/17/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
RSLN-0954	Nurse Exam Room 3	1092D1	Ice Machine	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0955	Cafeteria	1101	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0956	Cafeteria	1101	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0957	Kitchen Serving Line	1102A	Kitchen Faucet (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0958	Kitchen	1102	Kitchen Faucet (Cold)	Potable	1/29/2025	7.4	2/17/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
RSLN-0959	Kitchen	1102	Spray Nozzle	RFI	1/29/2025	43.3			Outlet Permanently Removed
RSLN-0960	Kitchen	1102	Pasta Pot/Steam Kettle	RFI	1/29/2025	6.1			Outlet Permanently Removed
RSLN-0961	Kitchen	1102	Spray Nozzle	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0962	Corridor Room 209 To 214 (Across Room 210)	2020	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0963	Corridor Room 209 To 214 (Across Room 210)	2020	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0964	Social Studies Offices	2008	Spray Nozzle	Potable	1/29/2025	5.3	2/17/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
RSLN-0965	Room 224	2033	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0966	Room 224	2033	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0967	Room 230	2034	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use

# Roslyn High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0968	Room 230	2034	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0969	Prep Area Between Room 230 & 231	2034A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0970	Prep Area Between Room 230 & 231	2034A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0971	Prep Area Between Room 230 & 231	2034A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0972	Chemical Prep Room (Refrigerator)	2034A1	Water Cooler	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0973	Chemical Prep Room (Refrigerator)	2034A1	Ice Machine	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0974	Room 231	2036	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0975	Room 231	2036	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0976	Room 232	2039	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0977	Room 232	2039	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0978	Room 232 (Refrigerator)	2039	Water Cooler	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0979	Room 232 (Refrigerator)	2039	Ice Machine	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0980	Math Offices	2046	Bottled Water Dispenser (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0981	Math Offices	2046	Bottled Water Dispenser (Hot)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0982	Room 302	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0983	Room 302	3001	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0984	Room 302	3001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0985	Room 302 (Refrigerator)	3001	Water Cooler	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0986	Room 302 (Refrigerator)	3001	Ice Machine	Non-Applicable					Placarded for Non-Drinking Use

# Hilltop Academy

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0701	Classroom	1002	Home Economics Faucet (Cold)	Potable	1/29/2025	1.8			Result Below Action Level Continue O&M
RSLN-0702	Classroom	1002	Home Economics Faucet (Cold)	Potable	1/29/2025	2.2			Result Below Action Level Continue O&M
RSLN-0908	Classroom Closet	1002A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0909	East Stairwell Men's Bathroom	1003A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0910	Women's Bathroom in Stairwell	2000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0911	2nd Floor Common Area	2001	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0912	2nd Floor Common Area	2001	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M


# Administration Building

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0716	Kitchen Bathroom	2006B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0749	Superintendent Office	2001	Kitchen Faucet (Cold)	Potable					Result Below Action Level Continue O&M
RSLN-0987	Restroom Adj. Stairwell 2nd Floor	2000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0988	Superintendent Office	2001	Kitchen Faucet (Cold)	Potable					
RSLN-0989	Superintendent Office Bathroom	2001A2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0990	Kitchen	2006	Kitchen Faucet (Cold)	Potable	1/29/2025	4.3			Result Below Action Level Continue O&M
RSLN-0991	Kitchen	2006	Bottled Water Dispenser (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0992	Kitchen	2006	Bottled Water Dispenser (Hot)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0993	First Floor Bathroom 1	1012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0994	First Floor Bathroom 2	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0995	Kitchen/Break Room	1014	Kitchen Faucet (Cold)	Potable	1/29/2025	2.1			Result Below Action Level Continue O&M
RSLN-0996	Kitchen/Break Room Custodial Closet	1014B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0997	Kitchen/Break Room	1014	Bottled Water Dispenser (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0998	Kitchen/Break Room	1014	Bottled Water Dispenser (Hot)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M

# Roslyn Maintenance Building

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
RSLN-0732	Shop Room	1011	Water Cooler	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0733	Bathroom	1013A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0734	Bathroom	1013A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0737	Bus Garage	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0739	Bus Garage Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0883	Shop Room	1011	Bottle Fill Station	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0884	Main Office Bathroom	1015C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0885	Main Office	1015	Bottled Water Dispenser (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0886	Main Office	1015	Bottled Water Dispenser (Hot)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0887	Bathroom Vestibule	1013	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0888	Bus Garage	N/A	Bottled Water Dispenser (Cold)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0889	Bus Garage	N/A	Bottled Water Dispenser (Hot)	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-0890	Bus Garage	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-0891	Bus Garage	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
RSLN-1007	Lounge	1014	Water Fountain-No Chiller	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-1008	Lounge	1014	Pasta Pot/Steam Kettle	Potable	1/29/2025	<1.00 ND			Result Below Action Level Continue O&M
RSLN-1009	Lounge	1014	Kitchen Faucet (Cold)	Potable	1/29/2025	18.3	2/17/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M

Attachment 3:  
  
Laboratory  
Analytical Reports




**J.C. Broderick & Associates, Inc.**

*Environmental Consulting & Testing*

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: East Hills Elementary School  
EHS

# ED50498

Client: Roslyn Union Free School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush



Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0007	CR	1001	Room 44	DW	1/28/2025	5:22:00 AM
RSLN-0015	CR	1007	Room 46	DW	1/28/2025	5:20:00 AM
RSLN-0016	CR	1009	Room 47	DW	1/28/2025	5:21:00 AM
RSLN-0018	CR	1010	Room 41	DW	1/28/2025	5:18:00 AM
RSLN-0020	CR	1011	Room 48	DW	1/28/2025	5:19:00 AM
RSLN-0022	CR	1012	Room 40	DW	1/28/2025	5:16:00 AM
RSLN-0024	CR	1013	Room 49	DW	1/28/2025	5:17:00 AM
RSLN-0026	CR	1014	Room 39	DW	1/28/2025	5:18:00 AM
RSLN-0028	CR	1015	Room 50	DW	1/28/2025	5:14:00 AM
RSLN-0029	HA	1025	Corridor Library To Room 47 (Outside Room 50)	WF	1/28/2025	5:13:00 AM
RSLN-0039	NO	1031A	Room 5 Health Office	NS	1/28/2025	5:12:00 AM
RSLN-0041	HA	1051	Corridor Room 19 To Room 22 (Outside Gym)	WF	1/28/2025	5:04:00 AM
RSLN-0049	CR	1046	Room 18	DW	1/28/2025	5:10:00 AM
RSLN-0054	CR	1048	Room 20	DW	1/28/2025	5:10:00 AM
RSLN-0057	CR	1049	Room 21	DW	1/28/2025	5:09:00 AM
RSLN-0060	CR	1050	Room 22	DW	1/28/2025	5:08:00 AM
RSLN-0064	CR	1056	Room 23	DW	1/28/2025	5:02:00 AM
RSLN-0067	CR	1057	Room 24	DW	1/28/2025	5:03:00 AM

Pro200 & SA 2/13/25

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY

JAN 30 2025 PM03:59

**Building Address**

400 round Hill Road  
Roslyn Heights, NY 11577


Analysis Type: ELAP 200.5

Lab Received: A. Minnifield  
Signature: A. Minnifield

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy

JCB Project Manager: Anthony Lombardi



# Lead in Water: Chain of Custody for

# ED 50498

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: East Hills Elementary School  
EHS

Client: Roslyn Union Free School District  
Retest/New Install [ ]  
Turn Around: Normal 1 wk / Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0072	CR	1058	Room 25	DW	1/28/2025	5:03:00 AM
RSLN-0073	KI	1061A	Kitchen	KC	1/28/2025	4:52:00 AM
RSLN-0074	KI	1061A	Kitchen	KC	1/28/2025	4:52:00 AM
RSLN-0075	KI	1061A	Kitchen	KC	1/28/2025	4:53:00 AM
RSLN-0076	KI	1061A	Kitchen	KC	1/28/2025	4:53:00 AM
RSLN-0077	KI	1061A	Kitchen	KC	1/28/2025	4:55:00 AM
RSLN-0078	KI	1061A	Kitchen	SN	1/28/2025	4:55:00 AM
RSLN-0079	KI	1061A	Kitchen	SN	1/28/2025	4:55:00 AM
RSLN-0082	CR	1062	Room 27	DW	1/28/2025	4:58:00 AM
RSLN-0084	CR	1063	Room 28	DW	1/28/2025	4:59:00 AM
RSLN-0089	CR	1064	Room 29	DW	1/28/2025	5:00:00 AM
RSLN-0095	CR	2001	Room 58	DW	1/28/2025	5:25:00 AM
RSLN-0097	CR	2002	Room 57	DW	1/28/2025	5:24:00 AM
RSLN-0100	CR	2005	Room 59	DW	1/28/2025	5:25:00 AM
RSLN-0102	CR	2006	Room 55	DW	1/28/2025	5:27:00 AM
RSLN-0104	CR	2007	Room 60	DW	1/28/2025	5:27:00 AM
RSLN-0106	CR	2008	Room 54	DW	1/28/2025	5:29:00 AM
RSLN-0108	CR	2009	Room 61	DW	1/28/2025	5:28:00 AM

RECEIVED  
ENGLANALYTICAL, INC.  
CARLE PLACE, NY

JAN 30 2025 PM 03:59


PH 200 8 884 - 2/13/25

**Building Address**  
400 round Hill Road  
Roslyn Heights , NY 11577

**Analysis Type:** ELAP 200.5

**Lab Recieved:** A. Minnifield  
**Signature:** *A. Minnifield*

**Samplers Name:** *Conor Malanaphy*  
**Samplers Signature:** *Conor Malanaphy*  
**JCB Project Manager:** *Anthony Lombardi*



# Lead in Water: Chain of Custody for

# ED50498

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 23-53787  
**Building:** East Hills Elementary School  
EHS

**Client:** Roslyn Union Free School District  
**Retest/New Install**   
**Turn Around:** Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0110	CR	2010	Room 53	DW	1/28/2025	5:31:00 AM
RSLN-0112	CR	2011	Room 62	DW	1/28/2025	5:30:00 AM
RSLN-0114	CR	2012	Room 52	DW	1/28/2025	5:32:00 AM
RSLN-0717	HA	1025	Corridor Library To Room 47 (Outside Room 50)	WC	1/28/2025	5:14:00 AM
RSLN-0718	HA	1051	Corridor Room 19 To Room 22 (Outside Gym)	WC	1/28/2025	5:05:00 AM
RSLN-0778	HA	1066	Corridor Room 27 To 29 (Outside Room 27)	WF	1/28/2025	4:57:00 AM
RSLN-0779	HA	1066	Corridor Room 27 To 29 (Outside Room 27)	WC	1/28/2025	4:58:00 AM
RSLN-0780	HA	2018	2nd Floor Corridor (Outside Room 51)	WF	1/28/2025	5:34:00 AM
RSLN-0781	HA	2018	2nd Floor Corridor (Outside Room 51)	WC	1/28/2025	5:33:00 AM
RSLN-0999	FL	1042	Room 17 Faculty Lounge	KC	1/28/2025	5:07:00 AM

Samples Submitted 46

RECEIVED  
EMSL ANALYTICALS INC.  
Carle Place, NY  
JAN 30 2025 PM03:59

**Building Address**  
400 round Hill Road  
Roslyn Heights, NY 11577

**Analysis Type:** ELAP 200.5

**Lab Received:** A. Minnifield

**Signature:** [Signature]

**Samplers Name:** Conor Malanaphy

**Samplers Signature:** [Signature]

**JCB Project Manager:** Anthony Lombardo

M2008 SA 2/3/25

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550498  
**LIMS Reference ID:** ED50498  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787, East Hills Elementary School, EHS,  
 Roslyn Union Free School District, 400 Round  
 Hill Road, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/30/2025 15:59  
**Reported:** 02/08/2025 10:53

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0007 Lims Reference ID: ED50498-01 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:07	02/01/25 14:07	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0015 Lims Reference ID: ED50498-02 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	2.9		1	1.0	µg/L	02/01/25 14:09	02/01/25 14:09	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0016 Lims Reference ID: ED50498-03 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:10	02/01/25 14:10	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0018 Lims Reference ID: ED50498-04 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:14	02/01/25 14:14	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0020 Lims Reference ID: ED50498-05 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:15	02/01/25 14:15	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0022 Lims Reference ID: ED50498-06 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:17	02/01/25 14:17	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0024 Lims Reference ID: ED50498-07 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:18	02/01/25 14:18	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0026 Lims Reference ID: ED50498-08 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:19	02/01/25 14:19	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0028 Lims Reference ID: ED50498-09 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:21	02/01/25 14:21	JH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550498  
**LIMS Reference ID:** ED50498  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787, East Hills Elementary School, EHS,  
 Roslyn Union Free School District, 400 Round  
 Hill Road, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/30/2025 15:59  
**Reported:** 02/08/2025 10:53

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0029 Lims Reference ID: ED50498-10 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:25	02/01/25 14:25	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0039 Lims Reference ID: ED50498-11 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:26	02/01/25 14:26	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0041 Lims Reference ID: ED50498-12 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:30	02/01/25 14:30	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0049 Lims Reference ID: ED50498-13 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:31	02/01/25 14:31	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0054 Lims Reference ID: ED50498-14 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:32	02/01/25 14:32	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0057 Lims Reference ID: ED50498-15 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:34	02/01/25 14:34	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0060 Lims Reference ID: ED50498-16 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:35	02/01/25 14:35	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0064 Lims Reference ID: ED50498-17 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:36	02/01/25 14:36	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0067 Lims Reference ID: ED50498-18 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 14:38	02/01/25 14:38	JH	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550498  
**LIMS Reference ID:** ED50498  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787, East Hills Elementary School, EHS,  
 Roslyn Union Free School District, 400 Round  
 Hill Road, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/30/2025 15:59  
**Reported:** 02/08/2025 10:53

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0084 Lims Reference ID: ED50498-28 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	1.3		1	1.0	µg/L	02/01/25 12:45	02/01/25 12:45	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0089 Lims Reference ID: ED50498-29 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 12:46	02/01/25 12:46	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0095 Lims Reference ID: ED50498-30 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	2.1		1	1.0	µg/L	02/01/25 12:50	02/01/25 12:50	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0097 Lims Reference ID: ED50498-31 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	1.6		1	1.0	µg/L	02/01/25 12:51	02/01/25 12:51	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0100 Lims Reference ID: ED50498-32 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 12:55	02/01/25 12:55	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0102 Lims Reference ID: ED50498-33 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 12:57	02/01/25 12:57	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0104 Lims Reference ID: ED50498-34 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 12:58	02/01/25 12:58	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0106 Lims Reference ID: ED50498-35 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 12:59	02/01/25 12:59	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0108 Lims Reference ID: ED50498-36 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 13:00	02/01/25 13:00	JH	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550498  
**LIMS Reference ID:** ED50498  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 23-53787, East Hills Elementary School, EHS,  
Roslyn Union Free School District, 400 Round  
Hill Road, Roslyn Heights, NY 11577  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/30/2025 15:59  
**Reported:** 02/08/2025 10:53

**Analytical Results**  
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0110 Lims Reference ID: ED50498-37 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 13:02	02/01/25 13:02	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0112 Lims Reference ID: ED50498-38 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/01/25 13:03	02/01/25 13:03	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0114 Lims Reference ID: ED50498-39 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:34	02/03/25 10:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0717 Lims Reference ID: ED50498-40 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:37	02/03/25 10:37	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0718 Lims Reference ID: ED50498-41 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 16:11	02/03/25 16:11	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0778 Lims Reference ID: ED50498-42 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 16:12	02/03/25 16:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0779 Lims Reference ID: ED50498-43 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 16:14	02/03/25 16:14	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0780 Lims Reference ID: ED50498-44 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 16:15	02/03/25 16:15	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0781 Lims Reference ID: ED50498-45 Matrix: Drinking Water Sampled: 01/28/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 16:16	02/03/25 16:16	SEH	EPA 200.8 (DA)/EPA 200.8





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550498  
**LIMS Reference ID:** ED50498  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 23-53787, East Hills Elementary School, EHS,  
Roslyn Union Free School District, 400 Round  
Hill Road, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/30/2025 15:59  
**Reported:** 02/08/2025 10:53

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550498  
**LIMS Reference ID:** ED50498  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 23-53787, East Hills Elementary School, EHS,  
Roslyn Union Free School District, 400 Round  
Hill Road, Roslyn Heights, NY 11577  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/30/2025 15:59  
**Reported:** 02/08/2025 10:53


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: \_\_\_\_\_

23-53787

Building: Administration Building

RAB

# ED50481


Client:

Roslyn Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush \_\_\_\_\_

Page



Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0990	KI	2006	Kitchen	KC	1/29/2025	6:39:00 AM
RSLN-0991	KI	2006	Kitchen	BWC	1/29/2025	6:39:00 AM
RSLN-0992	KI	2006	Kitchen	BWH	1/29/2025	6:39:00 AM
RSLN-0995	FL	1014	Kitchen/Break Room	KC	1/29/2025	6:37:00 AM
RSLN-0997	FL	1014	Kitchen/Break Room	BWC	1/29/2025	6:37:00 AM
RSLN-0998	FL	1014	Kitchen/Break Room	BWH	1/29/2025	6:37:00 AM

Samples Submitted 6

*Pb 200.8*  
*JCB 2/1/25*

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JAN 29 2025 PM12:20

**Building Address**

300 Harbor Hill Road

Roslyn Heights, NY 11577

Analysis Type: ELAP 200.5

Lab Received: *A. Minnifield*

Signature: *A. Minnifield*

Samplers Name: *Conor Malanaphy*

Samplers Signature: *Conor Malanaphy*

JCB Project Manager: *Anthony Lombardo*

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550481  
**LIMS Reference ID:** ED50481  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787, Administration Building, RAB,  
 Roslyn Union Free School District, 300 Harbor  
 Hill Road, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/29/2025 12:20  
**Reported:** 02/08/2025 09:52

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0990 Lims Reference ID: ED50481-01 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	4.3		1	1.0	µg/L	01/30/25 08:56	02/01/25 13:34	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0991 Lims Reference ID: ED50481-02 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	01/30/25 08:56	02/01/25 13:38	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0992 Lims Reference ID: ED50481-03 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	01/30/25 08:56	02/01/25 13:42	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0995 Lims Reference ID: ED50481-04 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	2.1		1	1.0	µg/L	01/30/25 08:56	02/01/25 13:43	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0997 Lims Reference ID: ED50481-05 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	01/30/25 08:56	02/01/25 13:45	JH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0998 Lims Reference ID: ED50481-06 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	01/30/25 08:56	02/01/25 13:46	JH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550481  
**LIMS Reference ID:** ED50481  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787, Administration Building, RAB,  
 Roslyn Union Free School District, 300 Harbor  
 Hill Road, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/29/2025 12:20  
**Reported:** 02/08/2025 09:52

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550481  
**LIMS Reference ID:** ED50481  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 23-53787, Administration Building, RAB,  
Roslyn Union Free School District, 300 Harbor  
Hill Road, Roslyn Heights, NY 11577  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/29/2025 12:20  
**Reported:** 02/08/2025 09:52


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.




# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 23-53787  
**Building:** Administration Building  
RAB

# ED50481

**Client:** Roslyn Union Free School District  
**Retest/New Install** [ ]  
**Turn Around:** Normal 1 wk Rush \_\_\_\_\_



Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0990	KI	2006	Kitchen	KC	1/29/2025	6:39:00 AM
RSLN-0991	KI	2006	Kitchen	BWC	1/29/2025	6:39:00 AM
RSLN-0992	KI	2006	Kitchen	BWH	1/29/2025	6:39:00 AM
RSLN-0995	FL	1014	Kitchen/Break Room	KC	1/29/2025	6:37:00 AM
RSLN-0997	FL	1014	Kitchen/Break Room	BWC	1/29/2025	6:37:00 AM
RSLN-0998	FL	1014	Kitchen/Break Room	BWH	1/29/2025	6:37:00 AM

Samples Submitted 6

*Pb 200.8*  
*JCB 2/1/25*

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JAN 29 2025 PM12:20

**Building Address**  
300 Harbor Hill Road  
Roslyn Heights, NY 11577

**Analysis Type:** ELAP 200.5

**Lab Received:** *A. Minnifield*  
**Signature:** *A. Minnifield*

**Samplers Name:** *Conor Malanaphy*  
**Samplers Signature:** *Conor Malanaphy*  
**JCB Project Manager:** *Anthony Lombardo*

EDS 0482




# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: Roslyn High School  
RHS

Client: Roslyn Union Free School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush



Ph 200.8 SA 2/3/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0493	HA	1004	Auditorium Vestibule	WC	1/29/2025	5:08:00 AM
RSLN-0502	CR	1016	Foreign Language Study Center	BWC	1/29/2025	5:13:00 AM
RSLN-0503	CR	1016	Foreign Language Study Center	KC	1/29/2025	5:13:00 AM
RSLN-0552	FL	1031	Room 124/125 Science Offices	KC	1/29/2025	5:26:00 AM
RSLN-0586	CR	1071B	English Prep Room Kitchen	KC	1/29/2025	5:45:00 AM
RSLN-0597	NO	1092	Nurses Office	NS	1/29/2025	5:55:00 AM
RSLN-0601	FL	1093	Faculty Lounge	KC	1/29/2025	5:58:00 AM
RSLN-0605	OF	1099K	Main Office Conference Room	KC	1/29/2025	6:06:00 AM
RSLN-0609	KI	1102	Kitchen	KC	1/29/2025	4:45:00 AM
RSLN-0610	KI	1102	Kitchen	KC	1/29/2025	4:45:00 AM
RSLN-0611	KI	1102	Kitchen	KC	1/29/2025	4:47:00 AM
RSLN-0612	KI	1102	Kitchen	KC	1/29/2025	4:48:00 AM
RSLN-0613	KI	1102	Kitchen	KC	1/29/2025	5:01:00 AM
RSLN-0614	KI	1102	Kitchen	KC	1/29/2025	4:54:00 AM
RSLN-0615	KI	1102	Kitchen	KC	1/29/2025	4:58:00 AM
RSLN-0617	KI	1102A	Kitchen Serving Line	KC	1/29/2025	4:44:00 AM
RSLN-0618	KI	1102A	Kitchen Serving Line	KC	1/29/2025	4:44:00 AM
RSLN-0619	KI	1102A	Kitchen Serving Line	KC	1/29/2025	4:46:00 AM

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JAN 29 2025 PM 12:21

**Building Address**

475 Round Hill Road  
Roslyn Heights, NY 11577

Analysis Type: ELAP 200.5

Lab Received: Aceto


Signature: [Signature]

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy

JCB Project Manager: Anthony Lombardo

Ph 200.8 [Signature] 2/14/25



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: Roslyn High School  
RHS

# ED50482

Client: Roslyn Union Free School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0624	HA	N/A	Corridor Outside North Gym	WC	1/29/2025	5:39:00 AM
RSLN-0625	HA	N/A	Corridor Outside North Gym	WC	1/29/2025	5:39:00 AM
RSLN-0627	HA	1054	Corridor Girls Locker Room-Main Gym (Outside GLR)	WC	1/29/2025	5:35:00 AM
RSLN-0635	OF	2008	Social Studies Offices	KC	1/29/2025	6:31:00 AM
RSLN-0638	CR	2024B	Training Room	IM	1/29/2025	6:27:00 AM
RSLN-0648	HA	2043	Science Corridor Rooms 224-232 (Outside Room 230)	WC	1/29/2025	6:23:00 AM
RSLN-0689	OF	2046	Math Offices	KC	1/29/2025	6:17:00 AM
RSLN-0691	CR	2057	Room 242	KC	1/29/2025	6:14:00 AM
RSLN-0745	HA	N/A	Corridor Outside North Gym	WF	1/29/2025	5:39:00 AM
RSLN-0747	HA	2043	Science Corridor Rooms 224-232 (Outside Room 230)	WF	1/29/2025	6:23:00 AM
RSLN-0750	FH	N/A	Field House	IM	1/29/2025	6:48:00 AM
RSLN-0752	EX	N/A	Exterior Water Fountain o/s Field House (By Track)	DW	1/29/2025	6:43:00 AM
RSLN-0765	HA	1054	Corridor Girls Locker Room-Main Gym (Outside GLR)	WC	1/29/2025	5:35:00 AM
RSLN-0770	LR	1048B	Girl's Locker Room	WF	1/29/2025	5:38:00 AM
RSLN-0771	LR	1048B	Girl's Locker Room	WC	1/29/2025	5:38:00 AM
RSLN-0790	HA	0009	Basement Corridor (Outside Room 1)	WF	1/29/2025	6:00:00 AM
RSLN-0791	HA	0009	Basement Corridor (Outside Room 1)	WC	1/29/2025	6:00:00 AM
RSLN-0792	HA	1098	Corridor Orchestra-Guidance (Outside Nurses Office)	WF	1/29/2025	5:54:00 AM

Post 2008  
2/3/25

RECEIVED  
EMSL ANALYTICAL, INC.  
CARLE PLACE, NY  
JAN 29 2025 PM 12:21

**Building Address**

475 Round Hill Road  
Roslyn Heights, NY 11577

**Analysis Type:** ELAP 200.5

**Lab Received:** *C. Faub*

**Signature:** *[Signature]*

**Samplers Name:** *Conor Malanapiny*

**Samplers Signature:** *Conor Malanapiny*

**JCB Project Manager:** *Anthony Lombardo*

475 200.8 2/3/25



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: Roslyn High School  
RHS

ED50482

Client: Roslyn Union Free School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush

Rh 200.8 SA -> 2/3/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0793	HA	1098	Corridor Orchestra-Guidance (Outside Nurses Office)	WC	1/29/2025	5:54:00 AM
RSLN-0794	HA	1081	Corridor Room 107-111 (Outside Room 100)	WF	1/29/2025	5:42:00 AM
RSLN-0795	HA	1081	Corridor Room 107-111 (Outside Room 100)	WC	1/29/2025	5:42:00 AM
RSLN-0796	LR	1051	Boys Locker Room	WF	1/29/2025	5:34:00 AM
RSLN-0797	LR	1051	Boys Locker Room	WC	1/29/2025	5:34:00 AM
RSLN-0798	HA	2027	Corridor O/S Athletics Rooms	WF	1/29/2025	6:28:00 AM
RSLN-0799	HA	2027	Corridor O/S Athletics Rooms	WC	1/29/2025	6:28:00 AM
RSLN-0800	HA	1034	Science Corridor (Outside Room 130)	WF	1/29/2025	5:23:00 AM
RSLN-0801	HA	1034	Science Corridor (Outside Room 130)	WC	1/29/2025	5:23:00 AM
RSLN-0804	CR	2068	Corridor Rooms 234-240 (Across Projection Booth)	WF	1/29/2025	6:14:00 AM
RSLN-0805	CR	2068	Corridor Rooms 234-240 (Across Projection Booth)	WC	1/29/2025	6:14:00 AM
RSLN-0913	FH	N/A	Field House	KC	1/29/2025	6:44:00 AM
RSLN-0914	HA	1004	Auditorium Vestibule	WF	1/29/2025	5:07:00 AM
RSLN-0915	HA	1004	Auditorium Vestibule	WC	1/29/2025	5:07:00 AM
RSLN-0916	CR	1016	Foreign Language Study Center	BWH	1/29/2025	5:14:00 AM
RSLN-0934	CR	1032	Room 123	KC	1/29/2025	5:27:00 AM
RSLN-0935	CR	1032	Room 123	SN	1/29/2025	5:28:00 AM
RSLN-0936	HA	1043	Corridor Between Main Gym And DECA (Outside Main Gym)	WC	1/29/2025	5:31:00 AM

RECEIVED  
ENGLANDY CALING INC.  
CARLE PLACE, NY  
JAN 29 2025 PM 12:21

**Building Address**  
475 Round Hill Road  
Roslyn Heights, NY 11577

16206.8 *Carmina Jones*  
2/4/25

**Analysis Type:** ELAP 200.5  
**Lab Received:** *Carle*  
**Signature:** *[Signature]*

**Samplers Name:** *Conor Maloney*  
**Samplers Signature:** *Conor Maloney*  
**JCB Project Manager:** *Anthony Lombardo*



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: Roslyn High School  
RHS

# ED 50482

Client: Roslyn Union Free School District  
Retest/New Install | |  
Turn Around: Normal 1 wk Rush

*P2008 SA 2/3/25*

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0937	HA	1043	Corridor Between Main Gym And DECA (Outside Main Gym)	WF	1/29/2025	5:31:00 AM
RSLN-0947	OF	1088M	Guidance Kitchen	BWC	1/29/2025	5:51:00 AM
RSLN-0948	OF	1088M	Guidance Kitchen	BWH	1/29/2025	5:51:00 AM
RSLN-0953	NO	1092D1	Nurse Exam Room 3	NS	1/29/2025	5:56:00 AM
RSLN-0954	NO	1092D1	Nurse Exam Room 3	IM	1/29/2025	5:57:00 AM
RSLN-0955	CR	1101	Cafeteria	WF	1/29/2025	5:05:00 AM
RSLN-0956	CR	1101	Cafeteria	WC	1/29/2025	5:05:00 AM
RSLN-0957	KI	1102A	Kitchen Serving Line	KC	1/29/2025	5:03:00 AM
RSLN-0958	KI	1102	Kitchen	KC	1/29/2025	5:01:00 AM
RSLN-0959	KI	1102	Kitchen	SN	1/29/2025	4:55:00 AM
RSLN-0960	KI	1102	Kitchen	PK	1/29/2025	4:54:00 AM
RSLN-0961	KI	1102	Kitchen	SN	1/29/2025	4:59:00 AM
RSLN-0962	HA	2020	Corridor Room 209 To 214 (Across Room 210)	WF	1/29/2025	6:30:00 AM
RSLN-0963	HA	2020	Corridor Room 209 To 214 (Across Room 210)	WC	1/29/2025	6:30:00 AM
RSLN-0964	OF	2008	Social Studies Offices	SN	1/29/2025	6:31:00 AM
RSLN-0980	OF	2046	Math Offices	BWC	1/29/2025	6:17:00 AM
RSLN-0981	OF	2046	Math Offices	BWH	1/29/2025	6:17:00 AM

RECEIVED  
ENGL ANALYTICAL INC.

Carle Place, NY  
JAN 29 2025 PM 12:21

### Building Address

475 Round Hill Road  
Roslyn Heights, NY 11577

Analysis Type: ELAP 200.5

Lab Received: Carle

Signature: [Signature]

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy

JCB Project Manager: Anthony Lombardo

*76 200.8 Notified on 2/4/25*

EDS0482



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: Roslyn High School  
RHS

Client: Roslyn Union Free School District  
Retest/New Install   
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 71

Pb 200.8  
2/3/25

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JAN 29 2025 PM12:22

**Building Address**  
475 Round Hill Road  
Roslyn Heights, NY 11577

Analysis Type: ELAP 200.5  
Lab Received: crack  
Signature: [Signature]

Samplers Name: Conor Malanaphy  
Samplers Signature: Conor Malanaphy  
JCB Project Manager: Anthony Lombardo

Pb 200.8 - 11041101/0101 2/4/25

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550482  
**LIMS Reference ID:** ED50482  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** JCB#: 23-53787, Roslyn High School, Roslyn Union Free School District, 475 Round Hill Road, Roslyn Heights, NY 11577  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/29/2025 12:21  
**Reported:** 02/08/2025 10:48

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: RSLN-0493</b> Lims Reference ID: ED50482-01 Matrix: Drinking Water <b>Sampled: 01/29/25 00:00:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:11	02/03/25 10:11	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0502</b> Lims Reference ID: ED50482-02 Matrix: Drinking Water <b>Sampled: 01/29/25 00:00:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 09:31	02/03/25 09:31	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0503</b> Lims Reference ID: ED50482-03 Matrix: Drinking Water <b>Sampled: 01/29/25 00:00:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 09:32	02/03/25 09:32	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0552</b> Lims Reference ID: ED50482-04 Matrix: Drinking Water <b>Sampled: 01/29/25 00:00:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 09:34	02/03/25 09:34	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0586</b> Lims Reference ID: ED50482-05 Matrix: Drinking Water <b>Sampled: 01/29/25 00:00:00</b>									
<b>Metals</b>									
Lead	1.8		1	1.0	µg/L	02/03/25 09:35	02/03/25 09:35	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0597</b> Lims Reference ID: ED50482-06 Matrix: Drinking Water <b>Sampled: 01/29/25 00:00:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 09:39	02/03/25 09:39	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0601</b> Lims Reference ID: ED50482-07 Matrix: Drinking Water <b>Sampled: 01/29/25 00:00:00</b>									
<b>Metals</b>									
Lead	1.1		1	1.0	µg/L	02/03/25 09:40	02/03/25 09:40	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0605</b> Lims Reference ID: ED50482-08 Matrix: Drinking Water <b>Sampled: 01/29/25 00:00:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 09:42	02/03/25 09:42	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0609</b> Lims Reference ID: ED50482-09 Matrix: Drinking Water <b>Sampled: 01/29/25 00:00:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 09:43	02/03/25 09:43	SEH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550482  
**LIMS Reference ID:** ED50482  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** JCB#: 23-53787, Roslyn High School, Roslyn Union Free School District, 475 Round Hill Road, Roslyn Heights, NY 11577  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/29/2025 12:21  
**Reported:** 02/08/2025 10:48

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0610 Lims Reference ID: ED50482-10 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 09:44	02/03/25 09:44	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0611 Lims Reference ID: ED50482-11 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	1.4		1	1.0	µg/L	02/03/25 09:46	02/03/25 09:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0612 Lims Reference ID: ED50482-12 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 09:49	02/03/25 09:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0613 Lims Reference ID: ED50482-13 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	2.8		1	1.0	µg/L	02/03/25 09:51	02/03/25 09:51	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0614 Lims Reference ID: ED50482-14 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 09:55	02/03/25 09:55	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0615 Lims Reference ID: ED50482-15 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 09:56	02/03/25 09:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0617 Lims Reference ID: ED50482-16 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 09:57	02/03/25 09:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0618 Lims Reference ID: ED50482-17 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 09:59	02/03/25 09:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0619 Lims Reference ID: ED50482-18 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/04/25 21:28	02/04/25 21:28	KT1	EPA 200.8 (Dig)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550482  
**LIMS Reference ID:** ED50482  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** JCB#: 23-53787, Roslyn High School, Roslyn Union Free School District, 475 Round Hill Road, Roslyn Heights, NY 11577  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/29/2025 12:21  
**Reported:** 02/08/2025 10:48

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0624 Lims Reference ID: ED50482-19 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:00	02/03/25 10:00	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0625 Lims Reference ID: ED50482-20 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:01	02/03/25 10:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0627 Lims Reference ID: ED50482-21 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:03	02/03/25 10:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0635 Lims Reference ID: ED50482-22 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 11:23	02/03/25 11:23	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0638 Lims Reference ID: ED50482-23 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:34	02/03/25 10:34	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0648 Lims Reference ID: ED50482-24 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:35	02/03/25 10:35	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0689 Lims Reference ID: ED50482-25 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	1.3		1	1.0	µg/L	02/03/25 10:37	02/03/25 10:37	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0691 Lims Reference ID: ED50482-26 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:48	02/03/25 10:48	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0745 Lims Reference ID: ED50482-27 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:52	02/03/25 10:52	SEH	EPA 200.8 (DA)/EPA 200.8





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550482  
**LIMS Reference ID:** ED50482  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** JCB#: 23-53787, Roslyn High School, Roslyn Union Free School District, 475 Round Hill Road, Roslyn Heights, NY 11577  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/29/2025 12:21  
**Reported:** 02/08/2025 10:48

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0804 Lims Reference ID: ED50482-46 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 14:55	02/03/25 14:55	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0805 Lims Reference ID: ED50482-47 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 14:56	02/03/25 14:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0913 Lims Reference ID: ED50482-48 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 14:58	02/03/25 14:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0914 Lims Reference ID: ED50482-49 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 15:02	02/03/25 15:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0915 Lims Reference ID: ED50482-50 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 15:03	02/03/25 15:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0916 Lims Reference ID: ED50482-51 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 15:04	02/03/25 15:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0934 Lims Reference ID: ED50482-52 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 15:06	02/03/25 15:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0935 Lims Reference ID: ED50482-53 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 15:07	02/03/25 15:07	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0936 Lims Reference ID: ED50482-54 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 15:08	02/03/25 15:08	SEH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550482  
**LIMS Reference ID:** ED50482  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** JCB#: 23-53787, Roslyn High School, Roslyn  
 Union Free School District, 475 Round Hill  
 Road, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/29/2025 12:21  
**Reported:** 02/08/2025 10:48

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0937 Lims Reference ID: ED50482-55 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	12.5		1	1.0	µg/L	02/03/25 15:12	02/03/25 15:12	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0947 Lims Reference ID: ED50482-56 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 15:14	02/03/25 15:14	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0948 Lims Reference ID: ED50482-57 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 15:18	02/03/25 15:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0953 Lims Reference ID: ED50482-58 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	48.7		1	1.0	µg/L	02/03/25 15:19	02/03/25 15:19	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0954 Lims Reference ID: ED50482-59 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 15:20	02/03/25 15:20	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0955 Lims Reference ID: ED50482-60 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 15:22	02/03/25 15:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0956 Lims Reference ID: ED50482-61 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 15:23	02/03/25 15:23	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0957 Lims Reference ID: ED50482-62 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 15:24	02/03/25 15:24	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0958 Lims Reference ID: ED50482-63 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	7.4		1	1.0	µg/L	02/03/25 15:26	02/03/25 15:26	SEH	EPA 200.8 (DA)/EPA 200.8





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550482  
**LIMS Reference ID:** ED50482  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** JCB#: 23-53787, Roslyn High School, Roslyn  
Union Free School District, 475 Round Hill  
Road, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/29/2025 12:21  
**Reported:** 02/08/2025 10:48

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550482  
**LIMS Reference ID:** ED50482  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** JCB#: 23-53787, Roslyn High School, Roslyn  
Union Free School District, 475 Round Hill  
Road, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/29/2025 12:21  
**Reported:** 02/08/2025 10:48


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

# ED50484

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787

Client: Roslyn Union Free School District

Building: Hilltop Academy

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush

HTA



Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0701	CR	1002	Classroom	EC	1/29/2025	6:52:00 AM
RSLN-0702	CR	1002	Classroom	EC	1/29/2025	6:52:00 AM
RSLN-0911	HA	2001	2nd Floor Common Area	WC	1/29/2025	6:53:00 AM
RSLN-0912	HA	2001	2nd Floor Common Area	WF	1/29/2025	6:53:00 AM

Samples Submitted 4

*Pb 200-8  
JCB 2/1/25*

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JAN 29 2025 PM12:20

**Building Address**

475 Round Hill Road

Roslyn Heights, NY 11577

Analysis Type: ELAP 200.5

Lab Received: A. Minnifield

Signature: *A. Minnifield*

Samplers Name: Conor Maloney

Samplers Signature: *Conor Maloney*

JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550484  
**LIMS Reference ID:** ED50484  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787 , Hilltop Academy, HTA, Roslyn  
 Union Free School District, 475 Round Hill  
 Road, Roslyn Heights , NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish

**Received:** 01/29/2025 12:20  
**Reported:** 02/08/2025 10:10

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: RSLN-0701</b>									
				<b>Lims Reference ID:</b>	<b>ED50484-01</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 01/29/25 00:00:00</b>	
<b>Metals</b>									
Lead	1.8		1	1.0	µg/L	01/30/25 08:56	02/01/25 13:47	JH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0702</b>									
				<b>Lims Reference ID:</b>	<b>ED50484-02</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 01/29/25 00:00:00</b>	
<b>Metals</b>									
Lead	2.2		1	1.0	µg/L	01/30/25 08:56	02/01/25 13:49	JH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0911</b>									
				<b>Lims Reference ID:</b>	<b>ED50484-03</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 01/29/25 00:00:00</b>	
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	01/30/25 08:56	02/01/25 13:50	JH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0912</b>									
				<b>Lims Reference ID:</b>	<b>ED50484-04</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 01/29/25 00:00:00</b>	
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	01/30/25 08:56	02/01/25 13:51	JH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550484  
**LIMS Reference ID:** ED50484  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787 , Hilltop Academy, HTA, Roslyn  
 Union Free School District, 475 Round Hill  
 Road, Roslyn Heights , NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish

**Received:** 01/29/2025 12:20  
**Reported:** 02/08/2025 10:10

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550484  
**LIMS Reference ID:** ED50484  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 23-53787 , Hilltop Academy, HTA, Roslyn  
Union Free School District, 475 Round Hill  
Road, Roslyn Heights , NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/29/2025 12:20  
**Reported:** 02/08/2025 10:10

**Notes and Definitions**


<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED50517



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53787

Building: Roslyn Middle School

RMS

Client:

Roslyn Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0353	CR	1014	Room 112	KC	1/29/2025	7:15:00 AM
RSLN-0362	HA	1021	Corridor (Girls BR-Elevator Vestibule) (Outside Room 112)	WC	1/29/2025	7:14:00 AM
RSLN-0367	HA	1072	Corridor (o/s Nurse's Office)	DW	1/29/2025	7:12:00 AM
RSLN-0368	HA	1072	Corridor (o/s Nurse's Office)	DW	1/29/2025	7:12:00 AM
RSLN-0376	HE	1035	Home & Career Lab Room 611	EC	1/29/2025	7:27:00 AM
RSLN-0377	HE	1035	Home & Career Lab Room 611	EC	1/29/2025	7:27:00 AM
RSLN-0378	HE	1035	Home & Career Lab Room 611	EC	1/29/2025	7:28:00 AM
RSLN-0379	HE	1035	Home & Career Lab Room 611	EC	1/29/2025	7:28:00 AM
RSLN-0380	LR	1036A	Girls Locker Room	DW	1/29/2025	7:29:00 AM
RSLN-0381	LR	1036A	Girls Locker Room	DW	1/29/2025	7:29:00 AM
RSLN-0386	HA	1045	Corridor (Custodial Storage-Corridor 1031) (Outside Aux Gym)	WF	1/29/2025	7:31:00 AM
RSLN-0387	HA	1045	Corridor (Custodial Storage-Corridor 1031) (Outside Aux Gym)	WC	1/29/2025	7:31:00 AM
RSLN-0393	KI	1040B2	Kitchen	KC	1/29/2025	7:34:00 AM
RSLN-0395	KI	1040B2	Kitchen	KC	1/29/2025	7:34:00 AM
RSLN-0396	KI	1040B2	Kitchen	KC	1/29/2025	7:35:00 AM
RSLN-0399	CA	1041	Cafeteria South	WC	1/29/2025	7:33:00 AM
RSLN-0409	FL	1048	Faculty Room	KC	1/29/2025	7:40:00 AM
RSLN-0417	OF	1060	Tech A (pupil personnel services)	KC	1/29/2025	7:45:00 AM

P2008 SA - 2/3/25

RECEIVED  
EMSL ANALYTICAL INC.  
Carle Place, NY  
JAN 31 2025 PM 10:38

**Building Address**

375 Locust Lane  
Roslyn Heights, NY 11577



Analysis Type: ELAP 200.5

Lab Received: A Stanley

Signature: [Signature]

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy

JCB Project Manager: Anthony Lombardo



# Lead in Water: Chain of Custody for

# ED50517

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53787

Building:

Roslyn Middle School

RMS

Client:

Roslyn Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0421	NO	1070	Health Office	NS	1/29/2025	7:50:00 AM
RSLN-0422	NO	1070A	Health Office Exam Room	NS	1/29/2025	7:50:00 AM
RSLN-0424	OF	N/A	Athletic Trainer Office	IM	1/29/2025	7:42:00 AM
RSLN-0741	HA	1072	Corridor (o/s Nurse's Office)	WC	1/29/2025	7:12:00 AM
RSLN-0782	HA	2023	2nd Floor Corridor	WC	1/29/2025	7:17:00 AM
RSLN-0783	HA	2023	2nd Floor Corridor	WC	1/29/2025	7:17:00 AM
RSLN-0806	HA	1061	Corridor (Tech A-Boys Bathroom) (Outside Tech A Office)	WF	1/29/2025	7:44:00 AM
RSLN-0807	HA	1061	Corridor (Tech A-Boys Bathroom) (Outside Tech A Office)	WC	1/29/2025	7:44:00 AM
RSLN-0850	OF	1060	Tech A (pupil personnel services)	BWC	1/29/2025	7:45:00 AM
RSLN-0851	OF	1060	Tech A (pupil personnel services)	BWH	1/29/2025	7:45:00 AM
RSLN-0852	KI	1040B2	Kitchen	KC	1/29/2025	7:35:00 AM
RSLN-0853	KI	1040B2	Kitchen	KC	1/29/2025	7:35:00 AM
RSLN-0865	HA	1021	Corridor (Girls BR-Elevator Vestibule) (Outside Room 112)	WF	1/29/2025	7:14:00 AM
RSLN-0867	HA	1038	Corridor (Room 611-Corridor 1031) (Outside Room 600)	WF	1/29/2025	7:24:00 AM
RSLN-0868	HA	1068	Corridor (Room 129-Exit) (Outside Room 133)	WC	1/29/2025	7:49:00 AM
RSLN-0869	HA	1068	Corridor (Room 129-Exit) (Outside Room 133)	WF	1/29/2025	7:49:00 AM
RSLN-0870	NO	1070	Health Office	IM	1/29/2025	7:52:00 AM
RSLN-1000	CR	1014	Room 112	SN	1/29/2025	7:55:00 AM

P2008 S/S 2/3/25

RECEIVED  
FMSI ANALYTICAL, INC.  
Carle Place, NY  
JAN 31 2025 7:55 AM '25

**Building Address**

375 Locust Lane

Roslyn Heights, NY 11577

**Analysis Type:** ELAP 200.5

**Lab Received:**

A Stanley

**Signature:**

[Signature]

**Samplers Name:**


Conor Malanaphy

**Samplers Signature:**

Conor Malanaphy

**JCB Project Manager:**

Anthony Lombardo



# Lead in Water: Chain of Custody for

# ED50517

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: Roslyn Middle School  
RMS

Client: Roslyn Union Free School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-1001	KI	1040B2	Kitchen	SN	1/29/2025	7:36:00 AM
RSLN-1002	KI	1040B2	Kitchen	SN	1/29/2025	7:37:00 AM

Samples Submitted 38

Pp 200.8 SFA 2/3/25

RECEIVED  
ENSL ANALYTICAL, INC.  
Carle Place, NY  
JAN 31 2025 PM10:39

**Building Address**

375 Locust Lane  
Roslyn Heights, NY 11577

Analysis Type: ELAP 200.5

Lab Received: A Stanley

Signature: [Signature]

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy

JCB Project Manager: Anthony Lombardo



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550517  
**LIMS Reference ID:** ED50517  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 375 Locust Lane Roslyn Heights, NY 11577,  
 23-53787, Roslyn Middle School, Roslyn Union  
 Free School District  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/31/2025 22:38  
**Reported:** 02/08/2025 10:57

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0381 Lims Reference ID: ED50517-10 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	3.2		1	1.0	µg/L	02/03/25 11:38	02/03/25 11:38	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0386 Lims Reference ID: ED50517-11 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 11:39	02/03/25 11:39	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0387 Lims Reference ID: ED50517-12 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 11:43	02/03/25 11:43	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0393 Lims Reference ID: ED50517-13 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 12:05	02/03/25 12:05	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0395 Lims Reference ID: ED50517-14 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 12:06	02/03/25 12:06	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0396 Lims Reference ID: ED50517-15 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 11:49	02/03/25 11:49	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0399 Lims Reference ID: ED50517-16 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 11:51	02/03/25 11:51	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0409 Lims Reference ID: ED50517-17 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 11:52	02/03/25 11:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0417 Lims Reference ID: ED50517-18 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	9.1		1	1.0	µg/L	02/03/25 11:53	02/03/25 11:53	SEH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550517  
**LIMS Reference ID:** ED50517  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 375 Locust Lane Roslyn Heights, NY 11577,  
 23-53787, Roslyn Middle School, Roslyn Union  
 Free School District  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/31/2025 22:38  
**Reported:** 02/08/2025 10:57

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0421 Lims Reference ID: ED50517-19 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 11:54	02/03/25 11:54	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0422 Lims Reference ID: ED50517-20 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	6.4		1	1.0	µg/L	02/03/25 11:56	02/03/25 11:56	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0424 Lims Reference ID: ED50517-21 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:39	02/03/25 10:39	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0741 Lims Reference ID: ED50517-22 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:40	02/03/25 10:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0782 Lims Reference ID: ED50517-23 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:41	02/03/25 10:41	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0783 Lims Reference ID: ED50517-24 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:45	02/03/25 10:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0806 Lims Reference ID: ED50517-25 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:46	02/03/25 10:46	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0807 Lims Reference ID: ED50517-26 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:48	02/03/25 10:48	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0850 Lims Reference ID: ED50517-27 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:49	02/03/25 10:49	SEH	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550517  
**LIMS Reference ID:** ED50517  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 375 Locust Lane Roslyn Heights, NY 11577,  
23-53787, Roslyn Middle School, Roslyn Union  
Free School District  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/31/2025 22:38  
**Reported:** 02/08/2025 10:57

**Analytical Results**  
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0851 Lims Reference ID: ED50517-28 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:50	02/03/25 10:50	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0852 Lims Reference ID: ED50517-29 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	3.7		1	1.0	µg/L	02/03/25 10:52	02/03/25 10:52	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0853 Lims Reference ID: ED50517-30 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:55	02/03/25 10:55	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0865 Lims Reference ID: ED50517-31 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 10:57	02/03/25 10:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0867 Lims Reference ID: ED50517-32 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 11:01	02/03/25 11:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0868 Lims Reference ID: ED50517-33 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 11:02	02/03/25 11:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0869 Lims Reference ID: ED50517-34 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 11:03	02/03/25 11:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0870 Lims Reference ID: ED50517-35 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 11:04	02/03/25 11:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-1000 Lims Reference ID: ED50517-36 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	3.3		1	1.0	µg/L	02/03/25 11:06	02/03/25 11:06	SEH	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550517  
**LIMS Reference ID:** ED50517  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 375 Locust Lane Roslyn Heights, NY 11577,  
23-53787, Roslyn Middle School, Roslyn Union  
Free School District  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/31/2025 22:38  
**Reported:** 02/08/2025 10:57

**Analytical Results**  
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: RSLN-1001</b>									
<b>Lims Reference ID: ED50517-37 Matrix: Drinking Water</b>						<b>Sampled: 01/29/25 00:00:00</b>			
<b>Metals</b>									
Lead	3.7		1	1.0	µg/L	02/03/25 11:07	02/03/25 11:07	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-1002</b>									
<b>Lims Reference ID: ED50517-38 Matrix: Drinking Water</b>						<b>Sampled: 01/29/25 00:00:00</b>			
<b>Metals</b>									
Lead	1.3		1	1.0	µg/L	02/03/25 11:08	02/03/25 11:08	SEH	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550517  
**LIMS Reference ID:** ED50517  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 375 Locust Lane Roslyn Heights, NY 11577,  
23-53787, Roslyn Middle School, Roslyn Union  
Free School District  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/31/2025 22:38  
**Reported:** 02/08/2025 10:57

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550517  
**LIMS Reference ID:** ED50517  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 375 Locust Lane Roslyn Heights, NY 11577,  
23-53787, Roslyn Middle School, Roslyn Union  
Free School District  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/31/2025 22:38  
**Reported:** 02/08/2025 10:57


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

# E050518

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: Harbor Hill Elementary School  
HHE

Client: Roslyn Union Free School District  
Retest/New Install | |  
Turn Around: Normal 1 wk Rush \_\_\_\_\_

Pb200-8 SA 2/3/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0133	CR	1003	Room 25	DW	1/29/2025	6:36:00 AM
RSLN-0135	CR	1004	Room 24	DW	1/29/2025	6:37:00 AM
RSLN-0137	CR	1005	Room 27	DW	1/29/2025	6:38:00 AM
RSLN-0139	CR	1006	Room 26	DW	1/29/2025	6:39:00 AM
RSLN-0142	CR	1007	Room 29	DW	1/29/2025	6:40:00 AM
RSLN-0144	CR	1009	Room 31	DW	1/29/2025	6:41:00 AM
RSLN-0147	CR	1011	Room 33	DW	1/29/2025	6:42:00 AM
RSLN-0155	GY	1018	Gym Vestibule	WF	1/29/2025	6:44:00 AM
RSLN-0161	NO	1029	Nurses Office	NS	1/29/2025	6:49:00 AM
RSLN-0163	CA	1030	Cafeteria/Auditorium	DW	1/29/2025	6:54:00 AM
RSLN-0164	KI	1031A	Kitchen	KC	1/29/2025	6:07:00 AM
RSLN-0165	KI	1031A	Kitchen	KC	1/29/2025	6:08:00 AM
RSLN-0166	KI	1031A	Kitchen	KC	1/29/2025	6:08:00 AM
RSLN-0167	KI	1031A	Kitchen	KC	1/29/2025	6:09:00 AM
RSLN-0168	KI	1031A	Kitchen	KC	1/29/2025	6:10:00 AM
RSLN-0180	CR	1053	Room 10	DW	1/29/2025	6:18:00 AM
RSLN-0184	CR	1054	Room 11	DW	1/29/2025	6:19:00 AM
RSLN-0189	CR	1056	Room 13	DW	1/29/2025	6:20:00 AM

RECEIVED  
EMC ANALYTICAL, INC.  
Carle Place, NY  
JAN 31 2025 PM 10:36

### Building Address

3 Glen Cove Road  
Greenvale, NY 11548



Pb200-8-KATHY JONES 2/14/25

Analysis Type: ELAP 200.5


Lab Recieved: 1/31/25 22:36

Signature: [Signature] KAY WAGNER

Samplers Name: Anthony Lombardo

Samplers Signature: [Signature]

JCB Project Manager: LOMBARDO



# Lead in Water: Chain of Custody for

**ED56518**

J. C. BRODERICK AND ASSOCIATES, INC.  
 1775 Expressway North Hauppauge, NY 11788  
 TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 23-53787  
**Building:** Harbor Hill Elementary School  
 HHE

**Client:**  
 Roslyn Union Free School District

**Retest/New Install**   
**Turn Around:** Normal 1 wk Rush

R0200 & SA -> 2/13/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0192	CR	1057	Room 14	DW	1/29/2025	6:21:00 AM
RSLN-0195	CR	1058	Room 15	DW	1/29/2025	6:22:00 AM
RSLN-0198	CR	1060	Room 18	DW	1/29/2025	6:24:00 AM
RSLN-0201	CR	1061	Room 17	DW	1/29/2025	6:24:00 AM
RSLN-0204	CR	N/A	Room 19	DW	1/29/2025	6:26:00 AM
RSLN-0205	CR	N/A	Room 20	DW	1/29/2025	6:29:00 AM
RSLN-0206	CR	N/A	Room 21	DW	1/29/2025	6:31:00 AM
RSLN-0207	CR	N/A	Room 22	DW	1/29/2025	6:32:00 AM
RSLN-0208	CR	N/A	Room 23	DW	1/29/2025	6:33:00 AM
RSLN-0219	SP	N/A	Multipurpose Room	DW	1/29/2025	7:01:00 AM
RSLN-0222	CR	2000	Room 50 Computer Lab	DW	1/29/2025	7:02:00 AM
RSLN-0224	CR	2001	Room 51	DW	1/29/2025	7:04:00 AM
RSLN-0226	CR	2002	Room 52	DW	1/29/2025	7:05:00 AM
RSLN-0228	CR	2003	Room 53	DW	1/29/2025	7:06:00 AM
RSLN-0230	CR	2004	Room 54	DW	1/29/2025	7:06:00 AM
RSLN-0232	CR	2005	Room 55	DW	1/29/2025	7:07:00 AM
RSLN-0234	CR	2006	Room 56	DW	1/29/2025	7:08:00 AM
RSLN-0236	CR	2007	Room 57	DW	1/29/2025	7:09:00 AM

RECEIVED  
 EMGL ANALYTICAL, INC.  
 Carle Place, NY  
 JAN 31 2025 8:10:00

**Building Address**  
 3 Glen Cove Road  
 Greenvale, NY 11548

R0200 & SA -> 2/14/25

**Analysis Type:** ELAP 200.5  
**Lab Received:** 1/31/25 12:36  
**Signature:** *[Signature]* / KAY WAGNER

**Samplers Name:** Anthony Lombardo  
**Samplers Signature:** *[Signature]*  
**JCB Project Manager:** LOMBARDO



# Lead in Water: Chain of Custody for

**ELAP 200.5**

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 23-53787  
**Building:** Harbor Hill Elementary School  
HHE

**Client:**  
Roslyn Union Free School District

**Retest/New Install** [ ]  
**Turn Around:** Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AMERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0239	CR	2008	Room 58	DW	1/29/2025	7:09:00 AM
RSLN-0483	HA	1018	Gym Vestibule	WF	1/29/2025	6:44:00 AM
RSLN-0729	CA	1030	Cafeteria/Auditorium	WF	1/29/2025	6:54:00 AM
RSLN-0730	GY	1018	Gym Vestibule	WF	1/29/2025	6:44:00 AM
RSLN-0784	HA	1051	Main Lobby Corridor (Outside Room 9)	WF	1/29/2025	6:15:00 AM
RSLN-0785	HA	1051	Main Lobby Corridor (Outside Room 9)	WC	1/29/2025	6:15:00 AM
RSLN-0786	HA	1012	Corridor Room 25 To Gymnasium (Outside Room 25)	WF	1/29/2025	6:35:00 AM
RSLN-0787	HA	1012	Corridor Room 25 To Gymnasium (Outside Room 25)	WC	1/29/2025	6:36:00 AM
RSLN-0788	HA	2012	Corridor Room 50 To Room 58 (Outside Room 58)	WF	1/29/2025	7:10:00 AM
RSLN-0789	HA	2012	Corridor Room 50 To Room 58 (Outside Room 58)	WC	1/29/2025	7:10:00 AM
RSLN-0897	FL	1041	Faculty Room	KC	1/29/2025	6:15:00 AM
RSLN-1005	NO	1029	Nurses Office	SN	1/29/2025	6:49:00 AM
RSLN-1006	NO	1029	Nurses Office	IM	1/29/2025	6:50:00 AM
RSLN-1010	KI	1031A	Kitchen	SN	1/29/2025	6:11:00 AM

Samples Submitted 50

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
JAN 31 2025 PM10:37

**Building Address**  
3 Glen Cove Road  
Greenvale, NY 11548

**Analysis Type:** ELAP 200.5

**Lab Received:** 1/31/25 22:36

**Signature:** [Signature] Kay Wagner

**Samplers Name:** Anthony Lombardo

**Samplers Signature:** [Signature]

**JCB Project Manager:** Lombardo

Pb 200.8 SA → 2/3/25

Pb 200.8 1/31/25 2/4/25

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550518  
**LIMS Reference ID:** ED50518  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** Harbor Hill Elementary School: 3 Glen Cove  
 Greenvale, NY 11548: Roslyn Union Free  
 School District: 23-53787  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/31/2025 22:36  
**Reported:** 02/11/2025 12:05

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: RSLN-0133</b> Lims Reference ID: ED50518-01 Matrix: Drinking Water <b>Sampled: 01/29/25 06:36:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 16:22	02/03/25 16:22	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0135</b> Lims Reference ID: ED50518-02 Matrix: Drinking Water <b>Sampled: 01/29/25 06:37:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 16:26	02/03/25 16:26	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0137</b> Lims Reference ID: ED50518-03 Matrix: Drinking Water <b>Sampled: 01/29/25 06:38:00</b>									
<b>Metals</b>									
Lead	5.4		1	1.0	µg/L	02/03/25 16:27	02/03/25 16:27	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0139</b> Lims Reference ID: ED50518-04 Matrix: Drinking Water <b>Sampled: 01/29/25 06:39:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 16:28	02/03/25 16:28	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0142</b> Lims Reference ID: ED50518-05 Matrix: Drinking Water <b>Sampled: 01/29/25 06:40:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 16:30	02/03/25 16:30	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0144</b> Lims Reference ID: ED50518-06 Matrix: Drinking Water <b>Sampled: 01/29/25 06:41:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/04/25 21:40	02/04/25 21:40	KT1	EPA 200.8 (Dig)/EPA 200.8
<b>Sample: RSLN-0147</b> Lims Reference ID: ED50518-07 Matrix: Drinking Water <b>Sampled: 01/29/25 06:42:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 16:31	02/03/25 16:31	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0155</b> Lims Reference ID: ED50518-08 Matrix: Drinking Water <b>Sampled: 01/29/25 06:44:00</b>									
<b>Metals</b>									
Lead	1.1		1	1.0	µg/L	02/03/25 16:32	02/03/25 16:32	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0161</b> Lims Reference ID: ED50518-09 Matrix: Drinking Water <b>Sampled: 01/29/25 06:49:00</b>									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 12:28	02/03/25 12:28	SEH	EPA 200.8 (DA)/EPA 200.8





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550518  
**LIMS Reference ID:** ED50518  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** Harbor Hill Elementary School: 3 Glen Cove  
 Greenvale, NY 11548: Roslyn Union Free  
 School District: 23-53787  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/31/2025 22:36  
**Reported:** 02/11/2025 12:05

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0219 Lims Reference ID: ED50518-28 Matrix: Drinking Water Sampled: 01/29/25 07:01:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:02	02/03/25 13:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0222 Lims Reference ID: ED50518-29 Matrix: Drinking Water Sampled: 01/29/25 07:02:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:03	02/03/25 13:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0224 Lims Reference ID: ED50518-30 Matrix: Drinking Water Sampled: 01/29/25 07:04:00									
<b>Metals</b>									
Lead	1.8		1	1.0	µg/L	02/03/25 13:18	02/03/25 13:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0226 Lims Reference ID: ED50518-31 Matrix: Drinking Water Sampled: 01/29/25 07:05:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:22	02/03/25 13:22	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0228 Lims Reference ID: ED50518-32 Matrix: Drinking Water Sampled: 01/29/25 07:06:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/04/25 21:41	02/04/25 21:41	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: RSLN-0230 Lims Reference ID: ED50518-33 Matrix: Drinking Water Sampled: 01/29/25 07:06:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:23	02/03/25 13:23	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0232 Lims Reference ID: ED50518-34 Matrix: Drinking Water Sampled: 01/29/25 07:07:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:24	02/03/25 13:24	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0234 Lims Reference ID: ED50518-35 Matrix: Drinking Water Sampled: 01/29/25 07:08:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:26	02/03/25 13:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0236 Lims Reference ID: ED50518-36 Matrix: Drinking Water Sampled: 01/29/25 07:09:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:30	02/03/25 13:30	SEH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550518  
**LIMS Reference ID:** ED50518  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** Harbor Hill Elementary School: 3 Glen Cove  
 Greenvale, NY 11548: Roslyn Union Free  
 School District: 23-53787

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/31/2025 22:36  
**Reported:** 02/11/2025 12:05

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0239 Lims Reference ID: ED50518-37 Matrix: Drinking Water Sampled: 01/29/25 07:09:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:31	02/03/25 13:31	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0483 Lims Reference ID: ED50518-38 Matrix: Drinking Water Sampled: 01/29/25 06:44:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:32	02/03/25 13:32	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0729 Lims Reference ID: ED50518-39 Matrix: Drinking Water Sampled: 01/29/25 06:54:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:33	02/03/25 13:33	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0730 Lims Reference ID: ED50518-40 Matrix: Drinking Water Sampled: 01/29/25 06:44:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:35	02/03/25 13:35	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0784 Lims Reference ID: ED50518-41 Matrix: Drinking Water Sampled: 01/29/25 06:15:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:36	02/03/25 13:36	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0785 Lims Reference ID: ED50518-42 Matrix: Drinking Water Sampled: 01/29/25 06:15:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:40	02/03/25 13:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0786 Lims Reference ID: ED50518-43 Matrix: Drinking Water Sampled: 01/29/25 06:35:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 13:41	02/03/25 13:41	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0787 Lims Reference ID: ED50518-44 Matrix: Drinking Water Sampled: 01/29/25 06:36:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 14:10	02/03/25 14:10	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0788 Lims Reference ID: ED50518-45 Matrix: Drinking Water Sampled: 01/29/25 07:10:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 14:12	02/03/25 14:12	SEH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550518  
**LIMS Reference ID:** ED50518  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** Harbor Hill Elementary School: 3 Glen Cove  
 Greenvale, NY 11548: Roslyn Union Free  
 School District: 23-53787  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/31/2025 22:36  
**Reported:** 02/11/2025 12:05

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0789 Lims Reference ID: ED50518-46 Matrix: Drinking Water Sampled: 01/29/25 07:10:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 14:13	02/03/25 14:13	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0897 Lims Reference ID: ED50518-47 Matrix: Drinking Water Sampled: 01/29/25 06:15:00									
<b>Metals</b>									
Lead	25.9		1	1.0	µg/L	02/03/25 14:14	02/03/25 14:14	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-1005 Lims Reference ID: ED50518-48 Matrix: Drinking Water Sampled: 01/29/25 06:59:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/03/25 14:16	02/03/25 14:16	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-1006 Lims Reference ID: ED50518-49 Matrix: Drinking Water Sampled: 01/29/25 06:50:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/04/25 21:43	02/04/25 21:43	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: RSLN-1010 Lims Reference ID: ED50518-50 Matrix: Drinking Water Sampled: 01/29/25 06:11:00									
<b>Metals</b>									
Lead	12.1		1	1.0	µg/L	02/04/25 21:44	02/04/25 21:44	KT1	EPA 200.8 (Dig)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550518  
**LIMS Reference ID:** ED50518  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** Harbor Hill Elementary School: 3 Glen Cove  
Greenvale, NY 11548: Roslyn Union Free  
School District: 23-53787

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/31/2025 22:36  
**Reported:** 02/11/2025 12:05

**Certified Analyses included in this Report**

Analyte	Certifications
<b><i>EPA 200.8 in Drinking Water</i></b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550518  
**LIMS Reference ID:** ED50518  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** Harbor Hill Elementary School: 3 Glen Cove  
Greenvale, NY 11548: Roslyn Union Free  
School District: 23-53787

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 01/31/2025 22:36  
**Reported:** 02/11/2025 12:05


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: Heights Elementary School


THS

# ED50552

Client: Roslyn Union Free School District

Retest/New Install   
Turn Around: Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0251	HA	0019	Corridor Gym To Room 1 (Outside Library)	WF	1/29/2025	5:19:00 AM
RSLN-0254	FL	0016	Faculty Lounge	KC	1/29/2025	5:20:00 AM
RSLN-0256	CR	0018	Room 2	DW	1/29/2025	5:21:00 AM
RSLN-0258	CR	0017	Room 1	DW	1/29/2025	5:22:00 AM
RSLN-0260	CR	1000	Room 11	DW	1/29/2025	5:16:00 AM
RSLN-0262	CR	1001	Room 12	DW	1/29/2025	5:17:00 AM
RSLN-0269	HA	1019	Corridor Room 11 To Room 15 (Outside Room 13)	WF	1/29/2025	5:13:00 AM
RSLN-0270	CR	1004	Room 13	DW	1/29/2025	5:14:00 AM
RSLN-0272	KI	1006A	Kitchen	KC	1/29/2025	5:26:00 AM
RSLN-0273	KI	1006A	Kitchen	KC	1/29/2025	5:27:00 AM
RSLN-0274	KI	1006A	Kitchen	KC	1/29/2025	5:28:00 AM
RSLN-0276	HA	1019	Corridor Room 11 To Room 15 (Room 10)	WF	1/29/2025	5:09:00 AM
RSLN-0279	NO	1016	Nurse's Office	IM	1/29/2025	5:08:00 AM
RSLN-0281	CR	1017	Room 15	DW	1/29/2025	5:05:00 AM
RSLN-0283	CR	1018	Room 14	DW	1/29/2025	5:06:00 AM
RSLN-0285	HA	1021	Breeze Way	WC	1/29/2025	5:03:00 AM
RSLN-0286	HA	1021	Breeze Way	WC	1/29/2025	5:03:00 AM
RSLN-0288	CR	1024	Room 32	DW	1/29/2025	5:00:00 AM



Ph 200-858-2161/25

**Building Address**

240 Willow Street  
Roslyn Heights, NY 11577


Analysis Type: ELAP 200.5


Lab Received: A. Minnifield  
Signature: [Signature]

Samplers Name: Anthony Lombardo

Samplers Signature: [Signature]

JCB Project Manager: Lombardo





# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: Heights Elementary School  
THS

# ED50652

Client: Roslyn Union Free School District

Retest/New Install   
Turn Around: Normal 1 wk Rush \_\_\_\_\_

B6200.8880 2/6/25

RECEIVED  
EMG ANALYTICAL INC.  
Call: 315-66-4411  
FEB 04 2025 PM 01:34

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0292	CR	1025	Room 28	DW	1/29/2025	4:59:00 AM
RSLN-0294	CR	1028	Room 29	DW	1/29/2025	4:58:00 AM
RSLN-0296	CR	1030	Room 33	DW	1/29/2025	4:57:00 AM
RSLN-0299	CR	1032	Room 34	DW	1/29/2025	4:56:00 AM
RSLN-0302	CR	1034	Room 30	DW	1/29/2025	4:55:00 AM
RSLN-0306	CR	1037	Room 31	DW	1/29/2025	4:54:00 AM
RSLN-0310	CR	2000	Room 27	DW	1/29/2025	5:34:00 AM
RSLN-0312	CR	2001	Room 24	DW	1/29/2025	5:36:00 AM
RSLN-0317	CR	2006	Room 25	DW	1/29/2025	5:38:00 AM
RSLN-0318	HA	2016	Second Floor Corridor (Outside Room 25)	WF	1/29/2025	5:39:00 AM
RSLN-0320	CR	2009	Room 23	DW	1/29/2025	5:39:00 AM
RSLN-0326	CR	2014	Room 22	DW	1/29/2025	5:40:00 AM
RSLN-0328	CR	2015	Room 21	DW	1/29/2025	5:41:00 AM
RSLN-0722	KI	1006A	Kitchen	KC	1/29/2025	5:28:00 AM
RSLN-0777	CR	N/A	Room 10	DW	1/29/2025	5:19:00 AM
RSLN-0899	HA	0019	Corridor Gym To Room 1 (Outside Library)	WC	1/29/2025	5:13:00 AM
RSLN-0900	HA	1019	Corridor Room 11 To Room 15 (Outside Room 13)	WC	1/29/2025	5:10:00 AM
RSLN-0901	HA	1021	Corridor Room 11 To Room 15 (Room 10)	WC	1/29/2025	5:03:00 AM

**Building Address**

240 Willow Street  
Roslyn Heights, NY 11577

Analysis Type: ELAP 200.5


Lab Received: A. Minnifield

Signature: A. Minnifield

Samplers Name: Anthony Lombardo

Samplers Signature: [Signature]

JCB Project Manager: Lombardo



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 23-53787  
**Building:** Heights Elementary School  
THS

# ED50552

**Client:** Roslyn Union Free School District

**Retest/New Install**   
**Turn Around:** Normal 1 wk Rush \_\_\_\_\_

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0902	HA	1021	Breeze Way	WF	1/29/2025	5:36:00 AM
RSLN-0907	HA	2016	Second Floor Corridor (Outside Room 25)	WF	1/29/2025	5:35:00 AM
RSLN-1003	KI	1006A	Cafeteria Kitchen	SN	1/29/2025	5:28:00 AM
RSLN-1004	KI	1006A	Cafeteria Kitchen	SN	1/29/2025	5:29:00 AM

Samples Submitted 40

P6200-8SA 2/16/25

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
FEB 04 2025 PM01:34

**Building Address**

240 Willow Street  
Roslyn Heights, NY 11577

**Analysis Type:** ELAP 200.5

**Lab Received:** A. Minnifield

**Signature:** *A. Minnifield*

**Samplers Name:** Anthony Lombardo

**Samplers Signature:** *[Signature]*

**JCB Project Manager:** LOMBARDO



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550552  
**LIMS Reference ID:** ED50552  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787, Heights Elementary School, THS,  
 Roslyn Union Free School District, 240 Willow  
 Street, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish

**Received:** 02/04/2025 13:34  
**Reported:** 02/08/2025 10:14

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0273 Lims Reference ID: ED50552-10 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 09:23	02/06/25 09:23	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0274 Lims Reference ID: ED50552-11 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 09:25	02/06/25 09:25	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0276 Lims Reference ID: ED50552-12 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 09:26	02/06/25 09:26	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0279 Lims Reference ID: ED50552-13 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 09:27	02/06/25 09:27	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0281 Lims Reference ID: ED50552-14 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	3.0		1	1.0	µg/L	02/06/25 09:29	02/06/25 09:29	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0283 Lims Reference ID: ED50552-15 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 09:30	02/06/25 09:30	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0285 Lims Reference ID: ED50552-16 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/05/25 16:36	02/05/25 16:36	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0286 Lims Reference ID: ED50552-17 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/05/25 16:40	02/05/25 16:40	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0288 Lims Reference ID: ED50552-18 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	1.0		1	1.0	µg/L	02/05/25 16:41	02/05/25 16:41	SEH	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550552  
**LIMS Reference ID:** ED50552  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787, Heights Elementary School, THS,  
 Roslyn Union Free School District, 240 Willow  
 Street, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish

**Received:** 02/04/2025 13:34  
**Reported:** 02/08/2025 10:14

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0318 Lims Reference ID: ED50552-28 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/05/25 16:59	02/05/25 16:59	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0320 Lims Reference ID: ED50552-29 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/05/25 17:03	02/05/25 17:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0326 Lims Reference ID: ED50552-30 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/05/25 17:04	02/05/25 17:04	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0328 Lims Reference ID: ED50552-31 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	1.0		1	1.0	µg/L	02/05/25 17:05	02/05/25 17:05	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0722 Lims Reference ID: ED50552-32 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/05/25 17:07	02/05/25 17:07	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0777 Lims Reference ID: ED50552-33 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	263		5	5.0	µg/L	02/05/25 17:18	02/05/25 17:18	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0899 Lims Reference ID: ED50552-34 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/05/25 17:09	02/05/25 17:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0900 Lims Reference ID: ED50552-35 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 09:45	02/06/25 09:45	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0901 Lims Reference ID: ED50552-36 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 09:49	02/06/25 09:49	SEH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550552  
**LIMS Reference ID:** ED50552  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787, Heights Elementary School, THS,  
 Roslyn Union Free School District, 240 Willow  
 Street, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/04/2025 13:34  
**Reported:** 02/08/2025 10:14

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: RSLN-0902</b>									
<b>Lims Reference ID: ED50552-37</b>						<b>Matrix: Drinking Water</b>		<b>Sampled: 01/29/25 00:00:00</b>	
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 09:50	02/06/25 09:50	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0907</b>									
<b>Lims Reference ID: ED50552-38</b>						<b>Matrix: Drinking Water</b>		<b>Sampled: 01/29/25 00:00:00</b>	
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 09:52	02/06/25 09:52	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-1003</b>									
<b>Lims Reference ID: ED50552-39</b>						<b>Matrix: Drinking Water</b>		<b>Sampled: 01/29/25 00:00:00</b>	
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 09:53	02/06/25 09:53	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-1004</b>									
<b>Lims Reference ID: ED50552-40</b>						<b>Matrix: Drinking Water</b>		<b>Sampled: 01/29/25 00:00:00</b>	
<b>Metals</b>									
Lead	1.2		1	1.0	µg/L	02/05/25 17:11	02/05/25 17:11	SEH	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550552  
**LIMS Reference ID:** ED50552  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 23-53787, Heights Elementary School, THS,  
Roslyn Union Free School District, 240 Willow  
Street, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/04/2025 13:34  
**Reported:** 02/08/2025 10:14

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550552  
**LIMS Reference ID:** ED50552  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 23-53787, Heights Elementary School, THS,  
Roslyn Union Free School District, 240 Willow  
Street, Roslyn Heights, NY 11577  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/04/2025 13:34  
**Reported:** 02/08/2025 10:14

**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550554  
**LIMS Reference ID:** ED50554  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** Roslyn Maintenance Building, 3 Parp Drive,  
 Greenvale, New York 11548, Roslyn Union  
 Free School District, #:23-53787

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish

**Received:** 02/04/2025 15:35  
**Reported:** 02/08/2025 10:20

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: RSLN-0732 Lims Reference ID: ED50554-01 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 09:57	02/06/25 09:57	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0883 Lims Reference ID: ED50554-02 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 09:58	02/06/25 09:58	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0885 Lims Reference ID: ED50554-03 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 10:00	02/06/25 10:00	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0886 Lims Reference ID: ED50554-04 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 10:01	02/06/25 10:01	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0888 Lims Reference ID: ED50554-05 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 10:02	02/06/25 10:02	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-0889 Lims Reference ID: ED50554-06 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 10:03	02/06/25 10:03	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-1007 Lims Reference ID: ED50554-07 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 10:07	02/06/25 10:07	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-1008 Lims Reference ID: ED50554-08 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/06/25 10:09	02/06/25 10:09	SEH	EPA 200.8 (DA)/EPA 200.8
Sample: RSLN-1009 Lims Reference ID: ED50554-09 Matrix: Drinking Water Sampled: 01/29/25 00:00:00									
<b>Metals</b>									
Lead	18.3		1	1.0	µg/L	02/06/25 10:13	02/06/25 10:13	SEH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550554  
**LIMS Reference ID:** ED50554  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** Roslyn Maintenance Building, 3 Parp Drive,  
 Greenvale, New York 11548, Roslyn Union  
 Free School District, #:23-53787

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/04/2025 15:35  
**Reported:** 02/08/2025 10:20

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550554  
**LIMS Reference ID:** ED50554  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** Roslyn Maintenance Building, 3 Parp Drive,  
Greenvale, New York 11548, Roslyn Union  
Free School District, #:23-53787

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/04/2025 15:35  
**Reported:** 02/08/2025 10:20

**Notes and Definitions**


<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EDS 0752



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: Roslyn High School  
RHS

Client:  
Roslyn Union Free School District

Retest/New Install [ ]  
Turn Around: Normal 1 wk Rush 2 day

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0937	HA	1043	Corridor Between Main Gym And DECA (Outside Main Gym)	WF	2/17/2025	6:29:00 AM
RSLN-0953	NO	1092D1	Nurse Exam Room 3	NS	2/17/2025	6:22:00 AM
RSLN-0958	KI	1102	Kitchen	KC	2/17/2025	6:33:00 AM
RSLN-0964	OF	2008	Social Studies Offices	SN	2/17/2025	6:26:00 AM

Samples Submitted 4

P6200.8 SA 2/19/25

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
FEB 18 25. AM 09:37



**Building Address**  
475 Round Hill Road  
Roslyn Heights, NY 11577

Analysis Type: ELAP 200.5  
Lab Received: [Signature]  
Signature: [Signature]

Samplers Name: Anthony Lombardo  
Samplers Signature: [Signature]  
JCB Project Manager: LOMBARDO





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550752  
**LIMS Reference ID:** ED50752  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** JCB#: 23-53787, Roslyn High School RHS,  
Roslyn Union Free School District, 475 Round  
Hill Road, Roslyn Heights, NY 11577  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/18/2025 09:07  
**Reported:** 02/19/2025 14:57

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550752  
**LIMS Reference ID:** ED50752  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** JCB#: 23-53787, Roslyn High School RHS,  
Roslyn Union Free School District, 475 Round  
Hill Road, Roslyn Heights, NY 11577  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/18/2025 09:07  
**Reported:** 02/19/2025 14:57


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53787  
Building: Heights Elementary School

THS

# ED 50754

Client: Roslyn Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush 2 day

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0777	CR	N/A	Room 10	DW	2/17/2025	6:38:00 AM

Samples Submitted 1

Pin 200.5 8/10 2/19/25

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
FEB 18 25, AM 09:04

**Building Address**

240 Willow Street  
Roslyn Heights, NY 11577

Analysis Type: ELAP 200.5


Lab Received: A. Minnifed

Signature: A. Minnifed  
2/18/25 9:04 AM

Samplers Name: Anthony Lombardo

Samplers Signature: [Signature]

JCB Project Manager: LOMBARDO





**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550754  
**LIMS Reference ID:** ED50754  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787, Heights Elementary School, THS,  
 Roslyn Union Free School District, 240 Willow  
 Street, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/18/2025 09:04  
**Reported:** 02/19/2025 14:53

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550754  
**LIMS Reference ID:** ED50754  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 23-53787, Heights Elementary School, THS,  
Roslyn Union Free School District, 240 Willow  
Street, Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/18/2025 09:04  
**Reported:** 02/19/2025 14:53

**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory


EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EDS0755

# WATER SAMPLING CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

**SITE:** Roslyn Maintenance Building  
**ADDRESS:** 3 Parp Drive, Greenvale, New York 11548  
**DATE:** 2/17/25  
**CLIENT:** Roslyn Union Free School District  
**PROJECT #:** 23-53787


**SAMPLER'S NAME:** Anthony Lombardo  
**SAMPLER'S SIGN:**   
**LABORATORY:** EMSL  
**TURNAROUND TIME:** 24 HOUR 12 HOUR 6 HOUR RUSH **OTHER** (2 day)  
**MANAGER:** LOMARDO

ANALYZE EACH MATERIAL TO 1<sup>ST</sup> POSITIVE

SAMPLE ID	FUNCTIONAL SPACE TYPE	COMMON ROOM NAME	OUTLET TYPE	SAMPLE DATE	SAMPLE TIME
RSLN-1009	FL	Lounge	KC	2/17/2025	7:12

RECEIVED  
 EMSL ANALYTICAL, INC.  
 Carle Place, NY  
 FEB 18 25, AM 09:07

P. 200.8 & 219/25  
 2/19/25

SUBMITTED BY (PRINT)	SIGNATURE	DATE	TIME	RECEIVED BY (PRINT)	SIGNATURE	DATE	TIME
				ofaek		2-18-25	907a
COMMENTS				ANALYST (PRINT)		DATE	TIME
EPA 200.8 in Drinking Water 							

## J.C. BRODERICK & ASSOCIATES

1775 Expressway Drive North ♦ HAUPPAUGE ♦ NEW YORK, 11788 ♦ PHONE: (631) 584-5492 ♦ FAX: (631) 584-3395







**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550755  
**LIMS Reference ID:** ED50755  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** JCB #: 23-53787, Roslyn Maintenance Building, 3 Parp Drive, Greenvale, New York 11548, Roslyn Union Free School District  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/18/2025 09:07  
**Reported:** 02/19/2025 14:50

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550755  
**LIMS Reference ID:** ED50755  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** JCB #: 23-53787, Roslyn Maintenance Building, 3 Parp Drive, Greenvale, New York 11548, Roslyn Union Free School District  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/18/2025 09:07  
**Reported:** 02/19/2025 14:50


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

# ED50757

**JCB #:** 23-53787  
**Building:** Harbor Hill Elementary School  
HHE

**Client:** Roslyn Union Free School District

**Retest/New Install** [ ]  
**Turn Around:** Normal 1 wk Rush 2 day



Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0137	CR	1005	Room 27	DW	2/17/2025	7:03:00 AM
RSLN-0206	CR	N/A	Room 21	DW	2/17/2025	7:01:00 AM
RSLN-0897	FL	1041	Faculty Room	KC	2/17/2025	7:05:00 AM

Samples Submitted 3

Passes 884  
2/19/25

RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
FEB 18 25, AM 09:03

**Building Address**  
3 Glen Cove Road  
Greenvale, NY 11548

**Analysis Type:** ELAP 200.5

**Lab Received:** A. Minnifield  
**Signature:** [Signature]

**Samplers Name:** Anthony Lombardo

**Samplers Signature:** [Signature]

**JCB Project Manager:** LOMBARDO

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550757  
**LIMS Reference ID:** ED50757  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787, Harbor Hill Elementary School,  
 HHE, Roslyn Union Free School District, 3 Glen  
 Cove Road, Greenvale, NY 11548

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/18/2025 09:03  
**Reported:** 02/19/2025 14:47

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: RSLN-0137</b>		<b>Lims Reference ID: ED50757-01</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 02/17/25 07:03:00</b>			
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/19/25 09:28	02/19/25 09:28	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0206</b>		<b>Lims Reference ID: ED50757-02</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 02/17/25 07:01:00</b>			
<b>Metals</b>									
Lead	< 1.0		1	1.0	µg/L	02/19/25 09:29	02/19/25 09:29	SEH	EPA 200.8 (DA)/EPA 200.8
<b>Sample: RSLN-0897</b>		<b>Lims Reference ID: ED50757-03</b>		<b>Matrix: Drinking Water</b>		<b>Sampled: 02/17/25 07:05:00</b>			
<b>Metals</b>									
Lead	2.0		1	1.0	µg/L	02/19/25 09:31	02/19/25 09:31	SEH	EPA 200.8 (DA)/EPA 200.8



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550757  
**LIMS Reference ID:** ED50757  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 23-53787, Harbor Hill Elementary School,  
HHE, Roslyn Union Free School District, 3 Glen  
Cove Road, Greenvale, NY 11548  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/18/2025 09:03  
**Reported:** 02/19/2025 14:47

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550757  
**LIMS Reference ID:** ED50757  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 23-53787, Harbor Hill Elementary School,  
HHE, Roslyn Union Free School District, 3 Glen  
Cove Road, Greenvale, NY 11548  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/18/2025 09:03  
**Reported:** 02/19/2025 14:47

**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

# EDS0758

**JCB #:**

23-53787

**Building:**

Roslyn Middle School

RMS

**Client:**

Roslyn Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush 2 day

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0417	OF	1060	Tech A (pupil personnel services)	KC	2/17/2025	6:48:00 AM
RSLN-0422	NO	1070A	Health Office Exam Room	NS	2/17/2025	6:51:00 AM

Samples Submitted 2



RECEIVED  
 EMSL ANALYTICAL, INC.  
 Carle Place, NY  
 FEB 18 25, AM 09:05

Pb 200.8 g/L 2/19/25

**Building Address**

375 Locust Lane

Roslyn Heights, NY 11577

**Analysis Type:** ELAP 200.5

**Lab Received:** S. Cherofsky 2/18/25

**Signature:** S. Cherofsky 9:05am

**Samplers Name:** Anthony Lombardo

**Samplers Signature:** [Signature]

**JCB Project Manager:** LOMBARDO



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550758  
**LIMS Reference ID:** ED50758  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** JCB #: 23-53787, Roslyn Middle School, 375  
 Locust Lane, Roslyn Heights, NY 11577,  
 Roslyn Union Free School District

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/18/2025 09:05  
**Reported:** 02/19/2025 14:43

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550758  
**LIMS Reference ID:** ED50758  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** JCB #: 23-53787, Roslyn Middle School, 375  
Locust Lane, Roslyn Heights, NY 11577,  
Roslyn Union Free School District

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/18/2025 09:05  
**Reported:** 02/19/2025 14:43


**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



# Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.  
1775 Expressway North Hauppauge, NY 11788  
TEL: (631) 584-5492 FAX: (631) 584-3395

**JCB #:** 23-53787  
**Building:** Heights Elementary School  
THS

ED 50846


**Client:**  
Roslyn Union Free School District

Retest/New Install   
Turn Around: Normal 1 wk Rush 2 day

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
RSLN-0777	CR	N/A	Room 10	DW	2/21/25	6:18 am

Samples Submitted 1

Pb 200.886 2/24/25



RECEIVED  
EMSL ANALYTICAL, INC.  
Carle Place, NY  
FEB 21 25, PM 02:49

**Building Address**

240 Willow Street  
Roslyn Heights, NY 11577

**Analysis Type:** ELAP 200.5

**Lab Received:** A Stanley 2/21/25  
**Signature:** [Signature] 2:49pm

**Samplers Name:** Anthony Lombardo

**Samplers Signature:** [Signature]

**JCB Project Manager:** LOMBARDO



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
 Telephone: 516.997.7251 Fax:856-786-5974  
 EMSL-CP-06

**EMSL Order ID:** 062550846  
**LIMS Reference ID:** ED50846  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
 J.C. Broderick & Associates [JCBR50]  
 1775 Expressway Drive North, Suite 1  
 Hauppauge, NY 11788  
 (631) 584-5492  
 alombardo@jcbroderick.com

**Project Name:** 23-53787, Heights Elementary School THS,  
 Roslyn Union Free School District, 240 Willow  
 Street Roslyn Heights, NY 11577

**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/21/2025 14:49  
**Reported:** 02/24/2025 11:06

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	06-NYSELAP

**List of Certifications**

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2025
06-NYSDOH	New York State Department of Health	11469	04/01/2025
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2025
06-California ELAP	California Water Boards	2339	04/01/2025
06-AIHA LAP	EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC-ELLAP Accredited	102344	08/01/2026

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514  
Telephone: 516.997.7251 Fax:856-786-5974  
EMSL-CP-06

**EMSL Order ID:** 062550846  
**LIMS Reference ID:** ED50846  
**EMSL Customer ID:** JCBR50

**Attention:** Anthony Lombardo  
J.C. Broderick & Associates [JCBR50]  
1775 Expressway Drive North, Suite 1  
Hauppauge, NY 11788  
(631) 584-5492  
alombardo@jcbroderick.com

**Project Name:** 23-53787, Heights Elementary School THS,  
Roslyn Union Free School District, 240 Willow  
Street Roslyn Heights, NY 11577  
**Customer PO:**  
**EMSL Sales Rep:** Jeromy Bish  
**Received:** 02/21/2025 14:49  
**Reported:** 02/24/2025 11:06

**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.


Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

# Attachment 4:

# Laboratory Certifications



**J.C. Broderick & Associates, Inc.**

*Environmental Consulting & Testing*

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2025  
Issued April 01, 2024

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. DANIEL CLARKE  
EMSL ANALYTICAL, INC.  
528 MINEOLA AVE.  
CARLE PLACE, NY 11514

NY Lab Id No: 11469

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Bacteriology**

Coliform, Total / E. coli (Qualitative)	SM 21, 23 9222A,B,C SM 20, 21-23 9223B (-04) (Colilert)
E. coli (Enumeration)	SM 21, 23 9222A,B,C
Heterotrophic Plate Count	SM 20, 21-23 9215B (-04)

**Metals I**

Lead, Total	EPA 200.5 EPA 200.8 Rev. 5.4
-------------	---------------------------------

**Miscellaneous**

Asbestos	EPA 100.2
----------	-----------



Serial No.: 68787

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to [elap@health.ny.gov](mailto:elap@health.ny.gov).

